

HAVEN RESIDENTIAL
EXCAVATION PLAN

REV #0

DESIGN CALCULATIONS
February 2, 2026

PREPARED BY:
SCOTT F CANNON, PE



MZB ENGINEERING, INC

[TEL:949.254.4792](tel:949.254.4792)

engineering@mzbinc.com

www.mzbinc.com

1192 Athlone Lane

Corona, CA

92882

Table of Contents

1. Drawings.....	1-4
2. 4 ft Vertical Slope Stability Analysis.....	5-68
3. 5 ft Vertical Slope Stability Analysis.....	69-129
4. Reference Documents.....	130-138



MZB ENGINEERING, INC

[TEL:949.254.4792](tel:949.254.4792)

engineering@mzbinc.com


www.mzbinc.com

PLANS FOR CONSTRUCTION ON
HAVEN RESIDENTIAL
 IN RIVERSIDE COUNTY
 -
STORM DRAIN EXCAVATION PLAN
REVISION 0

INDEX TO PLANS

SHEET NO.	TITLE
1	COVER
2	NOTES
3	4 FT - PLAN VIEW / SECTION VIEW
4	5 FT - PLAN VIEW / SECTION VIEW

LOCATION MAP



February 2, 2026



REV.	DATE	DESCRIPTION
0	1-31-26	ISSUED FOR CONSTRUCTION

DESIGN BY: S.CANNON
 DRAWN BY: S.CANNON
 SCALE: AS SHOWN

MZB ENGINEERING INC.
 engineering@mzbinc.com
 www.mzbinc.com
 1192 ATHLONE LANE
 CORONA, CA 92882
 (949) 254-4792



SEWER & WATER EXCAVATION	COVER	PROJECT: CITY OF MENIFEE	CONTRACTOR: KANA PIPELINE	CONTRACT NO: -
--------------------------	-------	--------------------------	---------------------------	----------------

SHEET NUMBER:
1
 OF 4 SHEETS
Haven File



GENERAL NOTES:

1. ALL EXCAVATIONS SHALL BE CONSTRUCTED AND MAINTAINED IN ACCORDANCE WITH OSHA CFR 29, PART 1926, SUBPART P, AND CAL/OSHA SAFETY ORDERS TITLE 8, SECTION 1504, AND 1539-1547.
2. THE DESIGN OF THIS TEMPORARY EXCAVATION IS IN ACCORDANCE WITH OCTA CONTRACT C-5-3843 AND TP SECTION 13 GEOTECHNICAL AND 22.4.5 EXCAVATIONS AND TRENCHES.
3. THE DESIGN OF THIS EXCAVATION IS IN ACCORDANCE WITH THE 2024 CALTRANS STANDARD SPECIFICATIONS AND THE 2011 CT TRENCHING AND SHORING MANUAL

LOCATION AND PROTECTION OF EXISTING UTILITIES:

1. THE CONTRACTOR SHALL VERIFY THE LOCATION OF ALL EXISTING UTILITIES, OTHER OBSTACLES, DIMENSIONS, OFFSETS, ELEVATIONS AND CONDITIONS IN THE FIELD PRIOR TO STARTING ANY WORK. ALL EXISTING UTILITIES SHOWN ON THE CONTRACT PLANS WITHIN THE WORK ZONE SHALL BE POSITIVELY IDENTIFIED PRIOR TO STARTING WORK. THE CONTRACTOR IS RESPONSIBLE TO POTHOLE ALL UTILITIES (AS NEEDED) BEFORE SHORING WALL CONSTRUCTION IS TO BEGIN. THE ENGINEER SHALL BE NOTIFIED OF ANY DISCREPANCIES OR INCONSISTENCIES BEFORE PROCEEDING FURTHER WITH THE WORK.

SURVEYING AND GROUND ELEVATION INFORMATION:

1. EXISTING GROUND ELEVATIONS AND CONSEQUENTIAL ELEVATION HEIGHTS HAVE BEEN DETERMINED BASED ON TOPOGRAPHICAL INFORMATION PROVIDED BY THE PLANS AND OR ACTUAL FIELD DATA.

COMPETENT PERSONS:

1. A COMPETENT PERSON IS CAPABLE OF IDENTIFYING EXISTING AND PREDICTABLE HAZARDS IN THE SURROUNDINGS, OR WORKING CONDITIONS WHICH ARE UNSANITARY, HAZARDOUS, OR DANGEROUS TO EMPLOYEES AND WHO HAS AUTHORIZATION TO TAKE PROMPT CORRECTIVE MEASURES TO ELIMINATE THEM.
2. BEFORE COMMENCING ANY EXCAVATION, THE CONTRACTOR SHALL OBTAIN UNDERGROUND SERVICE ALERT (USA) INQUIRY I.D. NUMBER. A MINIMUM OF 3 DAYS SHALL BE ALLOWED AFTER THE I.D. NUMBER IS OBTAINED AND BEFORE THE EXCAVATION WORK IS STARTED TO NOTIFY UTILITY OWNERS. IF THE UTILITY OWNER IS THE CITY, A CONFIRMATION NUMBER INDICATING THE CITY HAS BEEN NOTIFIED SHALL BE OBTAINED BY USA AND/OR THE CONTRACTOR FROM THE APPROPRIATE CITY DEPARTMENT. THE I.D. NUMBER TOGETHER WITH THE DATE ACQUIRED SHALL BE REPORTED TO THE INSPECTOR WHEN CALLING FOR INSPECTION. USA I.D. NUMBERS WILL NOT BE GIVEN MORE THAN TEN (10) WORK DAYS BEFORE STARTING EXCAVATION WORK.
3. THE CONTRACTORS COMPETENT PERSON SHALL BE ON-SITE OBSERVING THE EXCAVATION PROCESS AND SHALL BE THE RESPONSIBLE PARTY IN THE DETERMINATION OF THE SOIL TYPE EXPOSED IN THE EXCAVATION WALLS. IF THE SOIL TYPE ENCOUNTERED IS DIFFERENT THAN THAT SPECIFIED ON THE PLANS, THE DESIGN ENGINEER MUST BE NOTIFIED.
4. THE COMPETENT PERSON SHALL INSPECT THE TRENCH OR EXCAVATION AT THE BEGINNING OF EACH SHIFT PRIOR TO WORKERS ENTERING THE TRENCH OR EXCAVATION AND/OR IF WEATHER HAS CHANGED OR EFFECTED THE WORK AREA.

ENVIRONMENTAL/SWPPP COMPLIANCE:

1. DESIGN OF EXCAVATIONS IS BASED ON ASSUMPTIONS THAT SOIL PROPERTIES AND GROUND CONDITIONS REMAIN CONSTANT THROUGH THE LIFE OF THE EXCAVATION. WATER CAN EFFECT THE STRENGTH OF SOILS AND GREAT CARE SHOULD BE TAKEN TO PREVENT CHANGES FROM EXISTING SOIL CONDITIONS. SLOPES MUST BE PROTECTED FROM EXCESSIVE SOIL SATURATION AND EROSION DURING CONSTRUCTION. WATER PONDING IN THE BASE OF EXCAVATIONS IS UNACCEPTABLE AND SHOULD BE DIVERTED OR REMOVED. PROPER SWPPP AND BMP MEASURES SHALL BE USED TO PREVENT ENVIRONMENTAL INDUCED SLOPE INSTABILITY.

CAL/OSHA REQUIREMENTS:

1. A CAL/OSHA EXCAVATION PERMIT MUST BE OBTAINED PRIOR TO ANY EXCAVATION.
2. A COPY OF THIS SHORING PLAN MUST BE AT THE JOB SITE DURING CONSTRUCTION.
3. INGRESS AND EGRESS TO THE EXCAVATION SHALL CONFORM TO ALL OSHA REQUIREMENTS INCLUDING: HANDRAILS, LADDER ACCESS AND FALL PROTECTION AS REQUIRED.
4. CONTINGENCY PLANS FOR EMERGENCY SITUATIONS SHALL BE ADDRESSED IN JHA.

CONSTRUCTION REQUIREMENTS:

1. CONTACT THE DESIGN ENGINEER IF EXCAVATION SHOWS SIGNS OF SLOUGHING, SWELLING OR PUMPING.
2. CAUTION SHALL BE TAKEN WHEN EXCAVATIONS ARE ADJACENT TO TRAFFIC AND THE TRAVELING PUBLIC.
3. THESE EXCAVATIONS SHOULD NOT BE ALLOWED TO BECOME SATURATED OR TO DRY OUT.

CONTROLLING FIELD DIMENSIONS

1. THE FIELD SUPERINTENDENT WILL VERIFY ALL CONTROLLING FIELD DIMENSIONS BEFORE ORDERING, FABRICATING, OR INSTALLING SHORING. UPON APPROVAL BY THE DESIGN ENGINEER DIMENSIONS OF THE SHORING WILL BE ADJUSTED TO FIT THE ACTUAL DIMENSIONS.
2. IF AT ANY POINT THE EXCAVATION EXCEEDS THE DEPTH SHOWN ON THE PLANS BY MORE THAN 1FT, NOTIFY THE DESIGN ENGINEER IMMEDIATELY.

LAVENDER

SOIL LAYER DESCRIPTIONS:

1. THE FOLLOWING SOIL DESCRIPTIONS ARE ASSUMED TO BE PRESENT DURING EXCAVATION. IF SOILS DIFFER FROM THOSE DESCRIBED BELOW, STOP THE EXCAVATION AND CONSULT WITH THE DESIGN ENGINEER.
SOIL TYPES & DESCRIPTIONS:
0.0' TO 8.0' - (ML) SANDY SILT
8.0' TO 13.0' - (SM) SILTY SAND

DESIGN PARAMETERS:

EXCAVATION SLOPE DESIGN BASED ON BORING LOGS HS-1 TO HS-4 OF THE INFORMATION PROVIDED IN THE REPORT OF GEOTECHNICAL INVESTIGATION, RESIDENTIAL DEVELOPMENT NORTHWEST CORNER OF EVANS ROAD & GARBANI ROAD, CITY OF MENIFEE, CA DATED JANUARY 31, 2023.

SOIL PARAMETERS:

0.0' TO 8.0' 8.0' TO 13.0'
 $\gamma = 110$ PCF $\gamma = 110$ PCF
 $\Phi = 28^\circ$ $\Phi = 40^\circ$
 $S_u = 100$ PSF $S_u = 25$ PSF

DESIGN SURCHARGE PARAMETERS:

1. IF K-RAIL IS LESS THAN 2FT FROM TOP OF SLOPE IT MUST BE PINNED. SEE 2015 CALTRANS STANDARD PLAN T3B.
2. K-RAIL MAY NOT BE PLACED CLOSER THAN 3" FROM TOP OF SLOPE. (200PSF).
3. SLOPES WERE DESIGNED WITH A HS20-44 TRAFFIC SURCHARGE (300PSF) PLACED 2FT FROM TOP OF SLOPE OR AS SHOWN IN THE SURCHARGE TABLE(S) IN THESE PLANS.
4. FOR SURCHARGE OFFSETS REFER TO "ASSUMED SURCHARGES & MIN. OFFSETS" TABLES ON SECTION VIEWS..
5. IF HIGHER GROUND PRESSURE IS ANTICIPATED, CONSULT WITH THE DESIGN ENGINEER.

February 2, 2026



REV.	DATE	DESCRIPTION
0	1-31-26	ISSUED FOR CONSTRUCTION

DESIGN BY: SCANNON
DRAWN BY: SCANNON
SCALE: AS SHOWN

MZB ENGINEERING INC.
engineer@mzbinc.com
www.mzbinc.com
1192 ATHLONE LANE
CORONA, CA 92882
(949) 254-4792




SEWER & WATER EXCAVATION

NOTES


PROJECT: CITY OF MENIFEE
CONTRACTOR: KANA PIPELINE CONTRACT NO: -




SHEET NUMBER:
2
OF 4 SHEETS
Haven File



SITE PLAN
SCALE: 1:8
HAVEN




SECTION VIEW A
SCALE: 1:8
HAVEN



SECTION VIEW B
SCALE: 1:8
HAVEN

ASSUMED MINIMUM OFFSETS	
SURCHARGE	OFFSET
HS 20-44 TRAFFIC	5 FT
CAT 330 EXCAVATOR	3 FT
3 CY LOADER	7 FT
K-RAIL	2 FT
CONCRETE TRUCK	12 FT
SPOIL PILE*	3 FT

*SPOIL PILE HT = 8 FT W/ 1:1 SLOPE



Underground Service Alert

Call: TOLL FREE
1-800-422-4133

TWO WORKING DAYS BEFORE YOU DIG

REV.	DATE	DESCRIPTION
0	1-31-26	ISSUED FOR CONSTRUCTION

DESIGN BY: SCANNON
DRAWN BY: SCANNON
SCALE: AS SHOWN


MZB ENGINEERING INC.
 engineering@mzbinc.com
 www.mzbinc.com
 1192 ATHLONE LANE
 CORONA, CA 92882
 (949) 254-4792




SEWER & WATER EXCAVATION
4 FT - PLAN VIEW / SECTION VIEW
 PROJECT: CITY OF MENIFEE
 CONTRACTOR: KANA PIPELINE
 CONTRACT NO. -

SHEET NUMBER:
3
OF 4 SHEETS
Haven File


February 2, 2026



SITE PLAN
SCALE: 1:8
HAVEN




SECTION VIEW C
SCALE: 1:8
HAVEN



SECTION VIEW D
SCALE: 1:8
HAVEN

ASSUMED MINIMUM OFFSETS	
SURCHARGE	OFFSET
HS 20-44 TRAFFIC	5 FT
CAT 330 EXCAVATOR	3 FT
3 CY LOADER	9 FT
K-RAIL	2 FT
CONCRETE TRUCK	12 FT
SPOIL PILE*	3 FT

*SPOIL PILE HT = 8 FT W/ 1:1 SLOPE



Underground Service Alert

 Call: TOLL FREE
 1-800-422-4133
 TWO WORKING DAYS BEFORE YOU DIG

REV.	DATE	DESCRIPTION
0	1-31-26	ISSUED FOR CONSTRUCTION

DESIGN BY: SCANNON
 DRAWN BY: SCANNON
 SCALE: AS SHOWN

MZB ENGINEERING INC.
 engineering@mzbinc.com
 www.mzbinc.com
 1192 ATHLONE LANE
 CORONA, CA 92882
 (949) 254-4792



SEWER & WATER EXCAVATION
5 FT - PLAN VIEW / SECTION VIEW
 PROJECT: CITY OF MENIFEE
 CONTRACTOR: KANA PIPELINE CONTRACT NO. -

SHEET NUMBER:
4
 OF 4 SHEETS
Haven File

Slope Stability Analysis (4 ft Vertical)



[TEL:702.808.1295](tel:702.808.1295)

KORPI CANNON ENGINEERING, PLLC

Scott@korpicanon.com

www.korpieng.com

9608 AQUA HARBOR WAY

LAS VEGAS, NV

89178

=====

STABLPro for Windows, Version 2015.4.5

Upgraded from:
FHWA-PCSTABLE

Serial Number : 357267753

--Slope Stability Analysis--
Simplified Janbu, Simplified Bishop
or Spencer Method of Slices

=====

This program is licensed to :

Korpi Cannon Engineering PLLC
Las Vegas, NV, USA

Path to file locations :

D:\Dropbox\Korpi_Cannon_Engineering\Projects\KC-0119 - MZB Engineering\Design\Excav
- Shoring\12.0 Haven\Design\4 ft\

Name of input data file : 3. Excavator.sl4d
Name of output file : 3. Excavator.sl4o
Name of plot output file : 3. Excavator.sl4p

Time and Date of Analysis

Date: February 02, 2026 Time: 16:33:45

1

PROBLEM DESCRIPTION New Slope

BOUNDARY COORDINATES

4 Top Boundaries
5 Total Boundaries

Boundary No.	X-Left ft.	Y-Left ft.	X-Right ft.	Y-Right ft.	Soil Type Below Bnd
1	0.00	11.00	30.00	11.00	2
2	30.00	11.00	30.25	15.00	2
3	30.25	15.00	39.25	24.00	1
4	39.25	24.00	75.00	24.00	1
5	30.25	15.00	75.00	15.00	2

1

ISOTROPIC SOIL PARAMETERS

2 Type(s) of Soil

Soil Type No.	Total Unit Wt. pcf	Saturated Unit Wt. pcf	Cohesion Intercept psf	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant psf	Piez. Surface No.
1	110.0	110.0	100.0	28.0	0.00	0.0	0
2	110.0	110.0	25.0	41.0	0.00	0.0	0

1

BOUNDARY LOAD(S)

2 Load(s) Specified

Load No.	X-Left ft.	X-Right ft.	Intensity psf	Deflection (deg)
1	42.25	44.50	1031.0	0.0
2	50.75	53.00	1031.0	0.0

NOTE - Intensity Is Specified As A Uniformly Distributed Force Acting On A Horizontally Projected Surface.

1

A Critical Failure Surface Searching Method, Using A Random Technique For Generating Circular Surfaces, Has Been Specified.

100 Trial Surfaces Have Been Generated.

10 Surfaces Initiate From Each Of 10 Points Equally Spaced
Along The Ground Surface Between X = 0.00 ft.
and X = 30.00 ft.

Each Surface Terminates Between X = 34.00 ft.
and X = 75.00 ft.

Unless Further Limitations Were Imposed, The Minimum Elevation
At Which A Surface Extends Is Y = 0.00 ft.

2.60 ft. Line Segments Define Each Trial Failure Surface.

Restrictions Have Been Imposed Upon The Angle Of Initiation.
The Angle Has Been Restricted Between The Angles Of -25.0
And 0.0 deg.

1

Following Are Displayed The Ten Most Critical Of The Trial
Failure Surfaces Examined. They Are Ordered - Most Critical
First.

* * Safety Factors Are Calculated By The Modified Bishop Method * *

Failure Surface Specified By 12 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	23.33	11.00
2	25.88	10.48
3	28.48	10.38
4	31.06	10.69
5	33.56	11.40
6	35.92	12.50
7	38.07	13.96
8	39.96	15.74
9	41.55	17.80
10	42.79	20.08
11	43.65	22.54
12	43.92	24.00

Circle Center At X = 27.8 ; Y = 26.7 and Radius, 16.4

*** 1.352 ***

Individual data on the 16 slices

Slice No.	Width Ft	Weight Lbs	Water Force		Tie Force		Earthquake Force		Surcharge Load Lbs
			Top Lbs	Bot Lbs	Norm Lbs	Tan Lbs	Hor Lbs	Ver Lbs	
1	2.5	0.72E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2	2.6	0.16E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3	1.5	0.89E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4	0.2	0.67E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
5	0.8	0.43E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
6	2.5	0.17E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
7	2.4	0.20E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8	2.2	0.20E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
9	1.1	0.11E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
10	0.1	0.70E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
11	0.7	0.67E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
12	1.6	0.13E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
13	0.7	0.43E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
14	0.5	0.26E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.56E+03
15	0.9	0.26E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.89E+03
16	0.3	0.21E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.27E+03

Failure Surface Specified By 14 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	20.00	11.00
2	22.47	10.19
3	25.04	9.76
4	27.63	9.70
5	30.21	10.02
6	32.72	10.71
7	35.10	11.76
8	37.30	13.15
9	39.27	14.84

10	40.98	16.80
11	42.38	18.99
12	43.45	21.36
13	44.16	23.86
14	44.18	24.00

Circle Center At X = 26.7 ; Y = 27.5 and Radius, 17.8

*** 1.428 ***

1

Failure Surface Specified By 15 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.67	11.00
2	19.17	10.28
3	21.73	9.83
4	24.32	9.65
5	26.92	9.75
6	29.49	10.12
7	32.01	10.77
8	34.45	11.68
9	36.77	12.84
10	38.96	14.24
11	40.99	15.86
12	42.84	17.70
13	44.48	19.71
14	45.89	21.89
15	46.97	24.00

Circle Center At X = 24.7 ; Y = 34.1 and Radius, 24.5

*** 1.510 ***

Failure Surface Specified By 13 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	23.33	11.00

2	25.89	10.50
3	28.48	10.33
4	31.07	10.50
5	33.63	11.00
6	36.09	11.82
7	38.43	12.96
8	40.61	14.38
9	42.58	16.08
10	44.32	18.01
11	45.79	20.15
12	46.98	22.46
13	47.54	24.00

Circle Center At X = 28.5 ; Y = 30.5 and Radius, 20.2

*** 1.517 ***

1

Failure Surface Specified By 12 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	20.00	11.00
2	22.50	10.27
3	25.08	10.02
4	27.68	10.24
5	30.18	10.93
6	32.52	12.06
7	34.61	13.61
8	36.39	15.51
9	37.78	17.70
10	38.75	20.11
11	39.27	22.66
12	39.29	24.00

Circle Center At X = 25.2 ; Y = 24.2 and Radius, 14.2

*** 1.571 ***

Failure Surface Specified By 16 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.67	11.00
2	19.14	10.20
3	21.68	9.66
4	24.27	9.40
5	26.87	9.42
6	29.45	9.72
7	31.99	10.30
8	34.45	11.14
9	36.81	12.24
10	39.03	13.58
11	41.10	15.16
12	42.99	16.95
13	44.67	18.93
14	46.14	21.07
15	47.36	23.37
16	47.62	24.00

Circle Center At X = 25.4 ; Y = 33.6 and Radius, 24.3

*** 1.609 ***

1

Failure Surface Specified By 14 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	20.00	11.00
2	22.36	9.91
3	24.86	9.19
4	27.44	8.86
5	30.04	8.92
6	32.59	9.38
7	35.05	10.23
8	37.35	11.44
9	39.44	12.99
10	41.27	14.84
11	42.79	16.95
12	43.98	19.26
13	44.80	21.73
14	45.18	24.00

Circle Center At X = 28.3 ; Y = 25.8 and Radius, 17.0

*** 1.642 ***

Failure Surface Specified By 16 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.67	11.00
2	19.04	9.93
3	21.53	9.18
4	24.09	8.74
5	26.69	8.63
6	29.28	8.86
7	31.82	9.41
8	34.27	10.28
9	36.59	11.45
10	38.74	12.91
11	40.69	14.63
12	42.41	16.58
13	43.87	18.73
14	45.04	21.05
15	45.90	23.51
16	46.01	24.00

Circle Center At X = 26.2 ; Y = 29.1 and Radius, 20.5

*** 1.678 ***

1

Failure Surface Specified By 17 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.67	11.00
2	19.20	10.43
3	21.78	10.07
4	24.37	9.92
5	26.97	9.98
6	29.56	10.25
7	32.12	10.72

8	34.62	11.41
9	37.07	12.30
10	39.43	13.38
11	41.70	14.65
12	43.86	16.09
13	45.89	17.71
14	47.79	19.49
15	49.54	21.42
16	51.12	23.48
17	51.45	24.00

Circle Center At X = 24.9 ; Y = 41.9 and Radius, 32.0

*** 1.700 ***

Failure Surface Specified By 13 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	20.00	11.00
2	22.42	10.04
3	24.96	9.51
4	27.56	9.42
5	30.13	9.78
6	32.61	10.58
7	34.91	11.79
8	36.97	13.38
9	38.72	15.30
10	40.12	17.50
11	41.12	19.90
12	41.69	22.43
13	41.77	24.00

Circle Center At X = 26.8 ; Y = 24.5 and Radius, 15.1


*** 1.704 ***

1

Y A X I S F T

T 75.00 + * .*

300 PSF Traffic Surcharge
200 PSF K-Rail Surcharge



=====

STABLPro for Windows, Version 2015.4.5

Upgraded from:
FHWA-PCSTABLE

Serial Number : 357267753

--Slope Stability Analysis--
Simplified Janbu, Simplified Bishop
or Spencer Method of Slices

=====

This program is licensed to :

Korpi Cannon Engineering PLLC
Las Vegas, NV, USA

Path to file locations :

D:\Dropbox\Korpi_Cannon_Engineering\Projects\KC-0119 - MZB Engineering\Design\Excav
- Shoring\12.0 Haven\Design\

Name of input data file : 4. Traffic - Vert.sl4d
Name of output file : 4. Traffic - Vert.sl4o
Name of plot output file : 4. Traffic - Vert.sl4p

Time and Date of Analysis

Date: January 18, 2026 Time: 11:47:16

1

PROBLEM DESCRIPTION New Slope

BOUNDARY COORDINATES

4 Top Boundaries
5 Total Boundaries

Boundary No.	X-Left ft.	Y-Left ft.	X-Right ft.	Y-Right ft.	Soil Type Below Bnd
1	0.00	11.00	30.00	11.00	2
2	30.00	11.00	30.25	15.00	2
3	30.25	15.00	39.25	24.00	1
4	39.25	24.00	75.00	24.00	1
5	30.25	15.00	75.00	15.00	2

1

ISOTROPIC SOIL PARAMETERS

2 Type(s) of Soil

Soil Type No.	Total Unit Wt. pcf	Saturated Unit Wt. pcf	Cohesion Intercept psf	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant psf	Piez. Surface No.
1	110.0	110.0	100.0	28.0	0.00	0.0	0
2	110.0	110.0	25.0	40.0	0.00	0.0	0

1

BOUNDARY LOAD(S)

2 Load(s) Specified

Load No.	X-Left ft.	X-Right ft.	Intensity psf	Deflection (deg)
1	41.25	43.25	200.0	0.0
2	43.50	75.00	300.0	0.0

NOTE - Intensity Is Specified As A Uniformly Distributed Force Acting On A Horizontally Projected Surface.

1

A Critical Failure Surface Searching Method, Using A Random Technique For Generating Circular Surfaces, Has Been Specified.

100 Trial Surfaces Have Been Generated.

10 Surfaces Initiate From Each Of 10 Points Equally Spaced
Along The Ground Surface Between X = 0.00 ft.
and X = 30.20 ft.

Each Surface Terminates Between X = 36.00 ft.
and X = 75.00 ft.

Unless Further Limitations Were Imposed, The Minimum Elevation
At Which A Surface Extends Is Y = 0.00 ft.

2.60 ft. Line Segments Define Each Trial Failure Surface.

Restrictions Have Been Imposed Upon The Angle Of Initiation.
The Angle Has Been Restricted Between The Angles Of -25.0
And 0.0 deg.

1

Following Are Displayed The Ten Most Critical Of The Trial
Failure Surfaces Examined. They Are Ordered - Most Critical
First.

* * Safety Factors Are Calculated By The Modified Bishop Method * *

Failure Surface Specified By 14 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.78	11.00
2	19.29	10.34
3	21.87	9.99
4	24.47	9.94
5	27.06	10.21
6	29.59	10.78
7	32.04	11.65
8	34.37	12.81
9	36.54	14.23
10	38.53	15.91
11	40.31	17.81
12	41.84	19.91

13 43.12 22.17
 14 43.87 24.00

Circle Center At X = 23.5 ; Y = 31.7 and Radius, 21.8

*** 1.476 ***

Individual data on the 20 slices

Slice No.	Width Ft	Weight Lbs	Water Force		Tie Force		Earthquake Force		Surcharge Load Lbs
			Top Lbs	Bot Lbs	Norm Lbs	Tan Lbs	Hor Lbs	Ver Lbs	
1	2.5	0.91E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2	2.6	0.24E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3	2.6	0.30E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4	2.6	0.26E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
5	2.5	0.14E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
6	0.4	0.66E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
7	0.2	0.56E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8	1.8	0.90E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
9	2.3	0.15E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
10	2.2	0.16E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
11	0.9	0.71E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
12	1.1	0.86E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
13	0.7	0.58E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
14	1.1	0.79E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
15	0.9	0.58E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
16	0.6	0.29E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.12E+03
17	1.3	0.42E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.25E+03
18	0.1	0.24E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.26E+02
19	0.2	0.33E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
20	0.4	0.19E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.11E+03

Failure Surface Specified By 13 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	20.13	11.00
2	22.63	10.27
3	25.21	9.96

4	27.81	10.08
5	30.35	10.62
6	32.78	11.56
7	35.01	12.88
8	37.01	14.55
9	38.70	16.53
10	40.05	18.75
11	41.02	21.16
12	41.59	23.70
13	41.60	24.00

Circle Center At X = 25.8 ; Y = 25.9 and Radius, 15.9

*** 1.498 ***

1

Failure Surface Specified By 13 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	23.49	11.00
2	26.04	10.48
3	28.63	10.32
4	31.23	10.51
5	33.77	11.06
6	36.21	11.95
7	38.51	13.16
8	40.62	14.68
9	42.51	16.47
10	44.13	18.50
11	45.46	20.74
12	46.47	23.13
13	46.70	24.00

Circle Center At X = 28.5 ; Y = 29.3 and Radius, 19.0

*** 1.518 ***

Failure Surface Specified By 16 Coordinate Points

Point	X-Surf	Y-Surf
-------	--------	--------

No.	ft.	ft.
1	16.78	11.00
2	19.33	10.52
3	21.92	10.24
4	24.52	10.18
5	27.11	10.32
6	29.69	10.68
7	32.23	11.24
8	34.71	12.01
9	37.12	12.98
10	39.45	14.14
11	41.67	15.49
12	43.78	17.01
13	45.76	18.70
14	47.60	20.54
15	49.27	22.52
16	50.33	24.00

Circle Center At X = 24.0 ; Y = 42.2 and Radius, 32.0

*** 1.563 ***

1

Failure Surface Specified By 13 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	20.13	11.00
2	22.59	10.16
3	25.15	9.70
4	27.75	9.64
5	30.33	9.99
6	32.82	10.72
7	35.18	11.83
8	37.33	13.29
9	39.24	15.05
10	40.85	17.09
11	42.13	19.36
12	43.04	21.79
13	43.50	24.00

Circle Center At X = 26.8 ; Y = 26.5 and Radius, 16.9

*** 1.571 ***

Failure Surface Specified By 15 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.78	11.00
2	19.24	10.16
3	21.78	9.61
4	24.37	9.37
5	26.97	9.42
6	29.54	9.78
7	32.06	10.44
8	34.48	11.38
9	36.78	12.60
10	38.91	14.08
11	40.87	15.80
12	42.60	17.74
13	44.10	19.86
14	45.34	22.15
15	46.09	24.00

Circle Center At X = 25.2 ; Y = 31.6 and Radius, 22.3

*** 1.601 ***

1

Failure Surface Specified By 16 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.78	11.00
2	19.29	10.31
3	21.85	9.87
4	24.44	9.68
5	27.04	9.73
6	29.62	10.04
7	32.16	10.59
8	34.64	11.38
9	37.03	12.40
10	39.31	13.65

11	41.46	15.11
12	43.46	16.77
13	45.30	18.61
14	46.95	20.62
15	48.39	22.78
16	49.05	24.00

Circle Center At X = 25.2 ; Y = 36.8 and Radius, 27.1

*** 1.603 ***

Failure Surface Specified By 18 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	13.42	11.00
2	15.89	10.17
3	18.42	9.56
4	20.99	9.18
5	23.58	9.03
6	26.18	9.11
7	28.76	9.42
8	31.31	9.96
9	33.79	10.71
10	36.20	11.69
11	38.52	12.88
12	40.72	14.27
13	42.78	15.84
14	44.70	17.59
15	46.46	19.51
16	48.04	21.58
17	49.43	23.77
18	49.55	24.00

Circle Center At X = 24.0 ; Y = 38.3 and Radius, 29.3

*** 1.740 ***

1

Failure Surface Specified By 18 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	13.42	11.00
2	15.88	10.16
3	18.41	9.54
4	20.98	9.14
5	23.57	8.97
6	26.17	9.02
7	28.76	9.30
8	31.31	9.80
9	33.80	10.53
10	36.23	11.47
11	38.56	12.62
12	40.78	13.97
13	42.88	15.50
14	44.84	17.22
15	46.63	19.09
16	48.26	21.12
17	49.71	23.28
18	50.10	24.00

Circle Center At X = 24.3 ; Y = 38.7 and Radius, 29.8

*** 1.770 ***

Failure Surface Specified By 13 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	26.84	11.00
2	29.40	10.51
3	31.99	10.38
4	34.58	10.62
5	37.11	11.22
6	39.53	12.18
7	41.79	13.46
8	43.85	15.05
9	45.65	16.92
10	47.18	19.03
11	48.40	21.32
12	49.28	23.77
13	49.32	24.00


Circle Center At X = 31.6 ; Y = 28.7 and Radius, 18.4

*** 1.788 ***

1

	Y	A	X	I	S	F	T
	0.00	9.38	18.75	28.13	37.50	46.88	
X	0.00	+-----+*	+-----+	+-----+	+-----+	+-----+	+-----+
	-		
	9.38	+88		
	-1	...818.261		
A	18.75	+88.351610		
	-52.61* .*93.51...		
X	28.13	+83.1.834183.1.064.2.. .		
	-934512. ..*836512 .2. ./10.7436.1. 220.4 36.51 11/2		
I	37.50	+984 3 6.6984..3387.7484		
	-		
S	46.88	+		
	-		
	56.25	+		

3 CY Loader Surcharge



=====

STABLPro for Windows, Version 2015.4.5

Upgraded from:
FHWA-PCSTABLE

Serial Number : 357267753

--Slope Stability Analysis--
Simplified Janbu, Simplified Bishop
or Spencer Method of Slices

=====

This program is licensed to :

Korpi Cannon Engineering PLLC
Las Vegas, NV, USA

Path to file locations :

D:\Dropbox\Korpi_Cannon_Engineering\Projects\KC-0119 - MZB Engineering\Design\Excav
- Shoring\12.0 Haven\Design\

Name of input data file : 5. Loader - Vert.sl4d
Name of output file : 5. Loader - Vert.sl4o
Name of plot output file : 5. Loader - Vert.sl4p

Time and Date of Analysis

Date: January 18, 2026 Time: 11:53:25

1

PROBLEM DESCRIPTION New Slope

BOUNDARY COORDINATES

4 Top Boundaries
5 Total Boundaries

Boundary No.	X-Left ft.	Y-Left ft.	X-Right ft.	Y-Right ft.	Soil Type Below Bnd
1	0.00	11.00	30.00	11.00	2
2	30.00	11.00	30.25	15.00	2
3	30.25	15.00	38.25	23.00	1
4	38.25	23.00	75.00	23.00	1
5	30.25	15.00	75.00	15.00	2

1

ISOTROPIC SOIL PARAMETERS

2 Type(s) of Soil

Soil Type No.	Total Unit Wt. pcf	Saturated Unit Wt. pcf	Cohesion Intercept psf	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant psf	Piez. Surface No.
1	110.0	110.0	100.0	28.0	0.00	0.0	0
2	110.0	110.0	25.0	40.0	0.00	0.0	0

1

BOUNDARY LOAD(S)

2 Load(s) Specified

Load No.	X-Left ft.	X-Right ft.	Intensity psf	Deflection (deg)
1	45.25	47.00	4700.0	0.0
2	53.25	55.00	4700.0	0.0

NOTE - Intensity Is Specified As A Uniformly Distributed Force Acting On A Horizontally Projected Surface.

1

A Critical Failure Surface Searching Method, Using A Random Technique For Generating Circular Surfaces, Has Been Specified.

100 Trial Surfaces Have Been Generated.

10 Surfaces Initiate From Each Of 10 Points Equally Spaced
Along The Ground Surface Between X = 0.00 ft.
and X = 30.20 ft.

Each Surface Terminates Between X = 36.00 ft.
and X = 75.00 ft.

Unless Further Limitations Were Imposed, The Minimum Elevation
At Which A Surface Extends Is Y = 0.00 ft.

2.60 ft. Line Segments Define Each Trial Failure Surface.

Restrictions Have Been Imposed Upon The Angle Of Initiation.
The Angle Has Been Restricted Between The Angles Of -25.0
And 0.0 deg.

1

Following Are Displayed The Ten Most Critical Of The Trial
Failure Surfaces Examined. They Are Ordered - Most Critical
First.

* * Safety Factors Are Calculated By The Modified Bishop Method * *

Failure Surface Specified By 16 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.78	11.00
2	19.29	10.31
3	21.85	9.87
4	24.44	9.67
5	27.04	9.72
6	29.62	10.02
7	32.17	10.56
8	34.65	11.34
9	37.04	12.35
10	39.33	13.59
11	41.49	15.03
12	43.50	16.68

13	45.35	18.51
14	47.01	20.51
15	48.48	22.65
16	48.67	23.00

Circle Center At X = 25.2 ; Y = 37.0 and Radius, 27.3

*** 1.268 ***

Individual data on the 21 slices

Slice No.	Width Ft	Weight Lbs	Water Force		Tie Force		Earthquake Force		Surcharge Load Lbs
			Top Lbs	Bot Lbs	Norm Lbs	Tan Lbs	Hor Lbs	Ver Lbs	
1	2.5	0.95E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2	2.6	0.26E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3	2.6	0.35E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4	2.6	0.37E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
5	2.6	0.32E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
6	0.4	0.39E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
7	0.2	0.79E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8	1.9	0.12E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
9	2.5	0.20E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
10	2.4	0.23E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
11	1.2	0.13E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
12	1.1	0.12E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
13	2.1	0.20E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
14	0.0	0.43E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
15	2.0	0.16E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
16	1.7	0.10E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
17	0.1	0.50E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.47E+03
18	1.7	0.64E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.78E+04
19	0.0	0.39E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
20	1.5	0.23E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
21	0.2	0.37E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Failure Surface Specified By 16 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
-----------	------------	------------

1	16.78	11.00
2	19.33	10.52
3	21.92	10.24
4	24.52	10.17
5	27.11	10.31
6	29.69	10.66
7	32.23	11.21
8	34.72	11.97
9	37.14	12.92
10	39.47	14.07
11	41.70	15.40
12	43.82	16.90
13	45.82	18.57
14	47.67	20.40
15	49.37	22.37
16	49.83	23.00

Circle Center At X = 24.1 ; Y = 42.5 and Radius, 32.3

*** 1.305 ***

1

Failure Surface Specified By 15 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	20.13	11.00
2	22.49	9.91
3	24.98	9.15
4	27.55	8.73
5	30.15	8.68
6	32.73	8.98
7	35.25	9.63
8	37.65	10.61
9	39.90	11.92
10	41.95	13.52
11	43.75	15.39
12	45.29	17.49
13	46.52	19.78
14	47.43	22.21
15	47.61	23.00

Circle Center At X = 29.3 ; Y = 27.6 and Radius, 19.0

*** 1.371 ***

Failure Surface Specified By 12 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	26.84	11.00
2	29.40	10.51
3	31.99	10.37
4	34.58	10.61
5	37.11	11.20
6	39.54	12.15
7	41.80	13.42
8	43.87	15.00
9	45.70	16.85
10	47.24	18.94
11	48.48	21.23
12	49.14	23.00

Circle Center At X = 31.6 ; Y = 28.9 and Radius, 18.5

*** 1.371 ***

1

Failure Surface Specified By 10 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	30.20	14.21
2	32.72	13.57
3	35.32	13.41
4	37.90	13.73
5	40.37	14.53
6	42.66	15.76
7	44.68	17.40
8	46.36	19.38
9	47.65	21.64
10	48.12	23.00

Circle Center At X = 34.9 ; Y = 27.4 and Radius, 14.0

*** 1.377 ***

Failure Surface Specified By 14 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	23.49	11.00
2	25.91	10.05
3	28.44	9.47
4	31.04	9.26
5	33.63	9.44
6	36.17	10.00
7	38.60	10.93
8	40.86	12.21
9	42.91	13.80
10	44.71	15.68
11	46.21	17.81
12	47.38	20.13
13	48.19	22.60
14	48.26	23.00

Circle Center At X = 31.1 ; Y = 26.9 and Radius, 17.6

*** 1.389 ***

1

Failure Surface Specified By 17 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	13.42	11.00
2	15.89	10.17
3	18.41	9.56
4	20.99	9.18
5	23.58	9.02
6	26.18	9.09
7	28.76	9.40
8	31.31	9.92
9	33.80	10.67
10	36.21	11.64

11	38.53	12.81
12	40.74	14.19
13	42.82	15.75
14	44.75	17.49
15	46.52	19.39
16	48.12	21.44
17	49.12	23.00

Circle Center At X = 24.1 ; Y = 38.5 and Radius, 29.5

*** 1.401 ***

Failure Surface Specified By 10 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	23.49	11.00
2	26.03	10.47
3	28.63	10.49
4	31.17	11.06
5	33.53	12.16
6	35.59	13.74
7	37.28	15.72
8	38.51	18.01
9	39.22	20.51
10	39.37	23.00

Circle Center At X = 27.2 ; Y = 22.6 and Radius, 12.2

*** 1.446 ***

1

Failure Surface Specified By 17 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	13.42	11.00
2	15.88	10.16
3	18.41	9.54
4	20.98	9.13

5	23.57	8.96
6	26.17	9.00
7	28.76	9.28
8	31.31	9.77
9	33.81	10.49
10	36.24	11.42
11	38.57	12.55
12	40.81	13.89
13	42.91	15.41
14	44.88	17.11
15	46.69	18.97
16	48.34	20.98
17	49.71	23.00

Circle Center At X = 24.3 ; Y = 38.9 and Radius, 30.0

*** 1.453 ***

Failure Surface Specified By 15 Coordinate Points


Point No.	X-Surf ft.	Y-Surf ft.
1	16.78	11.00
2	19.24	10.16
3	21.78	9.61
4	24.37	9.36
5	26.97	9.41
6	29.54	9.77
7	32.06	10.42
8	34.49	11.35
9	36.79	12.57
10	38.93	14.04
11	40.89	15.75
12	42.64	17.67
13	44.15	19.79
14	45.41	22.06
15	45.79	23.00

Circle Center At X = 25.2 ; Y = 31.7 and Radius, 22.4

*** 1.513 ***

T 75.00 +
-
-
-
-
-
* *
* *

Concrete Truck Surchage Load



=====

STABLPro for Windows, Version 2015.4.5

Upgraded from:
FHWA-PCSTABLE

Serial Number : 357267753

--Slope Stability Analysis--
Simplified Janbu, Simplified Bishop
or Spencer Method of Slices

=====

This program is licensed to :

Korpi Cannon Engineering PLLC
Las Vegas, NV, USA

Path to file locations :

D:\Dropbox\Korpi_Cannon_Engineering\Projects\KC-0119 - MZB Engineering\Design\Excav
- Shoring\12.0 Haven\Design\

Name of input data file : 6. Concrete Truck - Vert.sl4d
Name of output file : 6. Concrete Truck - Vert.sl4o
Name of plot output file : 6. Concrete Truck - Vert.sl4p

Time and Date of Analysis

Date: January 18, 2026 Time: 11:56:40

1

PROBLEM DESCRIPTION New Slope

BOUNDARY COORDINATES

4 Top Boundaries
5 Total Boundaries

Boundary No.	X-Left ft.	Y-Left ft.	X-Right ft.	Y-Right ft.	Soil Type Below Bnd
1	0.00	11.00	30.00	11.00	2
2	30.00	11.00	30.25	15.00	2
3	30.25	15.00	39.25	24.00	1
4	39.25	24.00	75.00	24.00	1
5	30.25	15.00	75.00	15.00	2

1

ISOTROPIC SOIL PARAMETERS

2 Type(s) of Soil

Soil Type No.	Total Unit Wt. pcf	Saturated Unit Wt. pcf	Cohesion Intercept psf	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant psf	Piez. Surface No.
1	110.0	110.0	100.0	28.0	0.00	0.0	0
2	110.0	110.0	25.0	40.0	0.00	0.0	0

1

BOUNDARY LOAD(S)

1 Load(s) Specified

Load No.	X-Left ft.	X-Right ft.	Intensity psf	Deflection (deg)
1	51.25	55.25	3361.0	0.0

NOTE - Intensity Is Specified As A Uniformly Distributed Force Acting On A Horizontally Projected Surface.

1

A Critical Failure Surface Searching Method, Using A Random Technique For Generating Circular Surfaces, Has Been Specified.

100 Trial Surfaces Have Been Generated.

10 Surfaces Initiate From Each Of 10 Points Equally Spaced
Along The Ground Surface Between X = 0.00 ft.
and X = 30.20 ft.

Each Surface Terminates Between X = 36.00 ft.
and X = 75.00 ft.

Unless Further Limitations Were Imposed, The Minimum Elevation
At Which A Surface Extends Is Y = 0.00 ft.

2.60 ft. Line Segments Define Each Trial Failure Surface.

Restrictions Have Been Imposed Upon The Angle Of Initiation.
The Angle Has Been Restricted Between The Angles Of -25.0
And 0.0 deg.

1

Following Are Displayed The Ten Most Critical Of The Trial
Failure Surfaces Examined. They Are Ordered - Most Critical
First.

* * Safety Factors Are Calculated By The Modified Bishop Method * *

Failure Surface Specified By 14 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	26.84	11.00
2	29.44	10.94
3	32.04	11.09
4	34.62	11.43
5	37.16	11.96
6	39.66	12.69
7	42.09	13.61
8	44.45	14.71
9	46.71	15.99
10	48.87	17.44
11	50.91	19.05
12	52.83	20.80
13	54.60	22.71

14 55.64 24.00

Circle Center At X = 28.9 ; Y = 44.9 and Radius, 34.0

*** 1.308 ***

Individual data on the 19 slices

Slice No.	Width Ft	Weight Lbs	Water Force		Tie Force		Earthquake Force		Surcharge Load Lbs
			Top Lbs	Bot Lbs	Norm Lbs	Tan Lbs	Hor Lbs	Ver Lbs	
1	2.6	0.80E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2	0.6	0.25E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3	0.2	0.56E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4	1.8	0.96E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
5	2.6	0.19E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
6	2.5	0.25E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
7	2.1	0.25E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8	0.4	0.51E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
9	2.4	0.29E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
10	2.4	0.25E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
11	0.5	0.51E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
12	1.8	0.16E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
13	2.2	0.17E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
14	2.0	0.13E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
15	0.3	0.18E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
16	1.6	0.68E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.53E+04
17	1.8	0.44E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.60E+04
18	0.6	0.63E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.22E+04
19	0.4	0.10E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Failure Surface Specified By 14 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	26.84	11.00
2	29.44	10.83
3	32.04	10.89
4	34.62	11.18
5	37.17	11.70

6	39.66	12.45
7	42.07	13.42
8	44.39	14.60
9	46.59	15.99
10	48.66	17.56
11	50.58	19.32
12	52.33	21.24
13	53.90	23.31
14	54.34	24.00

Circle Center At X = 30.1 ; Y = 39.8 and Radius, 29.0

*** 1.347 ***

1

Failure Surface Specified By 12 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	30.20	14.21
2	32.79	14.03
3	35.39	14.08
4	37.98	14.35
5	40.53	14.85
6	43.03	15.57
7	45.45	16.51
8	47.79	17.65
9	50.01	19.00
10	52.11	20.53
11	54.07	22.24
12	55.76	24.00

Circle Center At X = 33.6 ; Y = 43.7 and Radius, 29.7

*** 1.395 ***

Failure Surface Specified By 18 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
-----------	------------	------------

1	16.78	11.00
2	19.29	10.35
3	21.85	9.89
4	24.44	9.64
5	27.04	9.59
6	29.64	9.75
7	32.21	10.12
8	34.75	10.68
9	37.23	11.44
10	39.65	12.40
11	41.99	13.54
12	44.22	14.87
13	46.35	16.37
14	48.35	18.03
15	50.21	19.84
16	51.93	21.79
17	53.49	23.88
18	53.56	24.00

Circle Center At X = 26.3 ; Y = 42.5 and Radius, 33.0

*** 1.460 ***

1

Failure Surface Specified By 13 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	30.20	14.21
2	32.76	13.76
3	35.35	13.57
4	37.95	13.66
5	40.53	14.02
6	43.05	14.64
7	45.50	15.52
8	47.84	16.65
9	50.05	18.02
10	52.11	19.61
11	53.99	21.41
12	55.67	23.39
13	56.09	24.00

Circle Center At X = 35.8 ; Y = 38.5 and Radius, 25.0

*** 1.504 ***

Failure Surface Specified By 13 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	20.13	11.00
2	22.63	10.27
3	25.21	9.96
4	27.81	10.08
5	30.35	10.62
6	32.78	11.56
7	35.01	12.88
8	37.01	14.55
9	38.70	16.53
10	40.05	18.75
11	41.02	21.16
12	41.59	23.70
13	41.60	24.00

Circle Center At X = 25.8 ; Y = 25.9 and Radius, 15.9

*** 1.507 ***

1

Failure Surface Specified By 14 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.78	11.00
2	19.29	10.34
3	21.87	9.99
4	24.47	9.94
5	27.06	10.21
6	29.59	10.78
7	32.04	11.65
8	34.37	12.81
9	36.54	14.23
10	38.53	15.91
11	40.31	17.81
12	41.84	19.91

13	43.12	22.17
14	43.87	24.00

Circle Center At X = 23.5 ; Y = 31.7 and Radius, 21.8

*** 1.555 ***

Failure Surface Specified By 13 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	30.20	14.21
2	32.66	13.37
3	35.21	12.87
4	37.81	12.71
5	40.40	12.89
6	42.95	13.42
7	45.40	14.28
8	47.72	15.46
9	49.86	16.94
10	51.78	18.69
11	53.46	20.67
12	54.86	22.87
13	55.38	24.00

Circle Center At X = 37.7 ; Y = 32.3 and Radius, 19.5

*** 1.582 ***

1

Failure Surface Specified By 13 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	20.13	11.00
2	22.59	10.16
3	25.15	9.70
4	27.75	9.64
5	30.33	9.99
6	32.82	10.72

7	35.18	11.83
8	37.33	13.29
9	39.24	15.05
10	40.85	17.09
11	42.13	19.36
12	43.04	21.79
13	43.50	24.00

Circle Center At X = 26.8 ; Y = 26.5 and Radius, 16.9

*** 1.631 ***

Failure Surface Specified By 19 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.78	11.00
2	19.35	10.59
3	21.93	10.32
4	24.53	10.19
5	27.13	10.20
6	29.72	10.35
7	32.31	10.63
8	34.87	11.06
9	37.41	11.62
10	39.92	12.32
11	42.38	13.15
12	44.79	14.11
13	47.15	15.21
14	49.45	16.42
15	51.68	17.76
16	53.84	19.22
17	55.91	20.78
18	57.89	22.46
19	59.53	24.00

Circle Center At X = 25.7 ; Y = 58.6 and Radius, 48.4

*** 1.650 ***

	Y	A	X	I	S	F	T
	0.00	9.38	18.75	28.13	37.50	46.88	


```

X  0.00 +-----+*-----+-----+-----+-----+
-
-      ..
-      .
-      ..
-      ...
9.38 +      .. ..
-      ...
-      ....
-      .....
-      .....4
A  18.75 +      ....4
-      .....6
-      .....4
-      .....
-      ....46
-      ....471
X  28.13 +      ....96.
-      ....46*  3*
-      .....
-      ....41.83
-      ....41.6
-      .....953.
I  37.50 +      .....21836.. .
-      .....21.976.  ..*
-      .....0853.976 .6. .
-      .....21.....7.  66
-      .....13.  ...97 7
-      .....8.53.. . ...
S  46.88 +      .....01.....
-      .....8.51 . ....
-      .....8532 ....
-      ..... 01532 .. /1
-      ..... 0 1 24
-      ..... ..51 21/
56.25 +      .....0..51
-      ..... 0..
-      ..... 0
-      .....
-      .....
-      .....
F  65.63 +      .....
-      .....
-      .....

```

T 75.00 + * *
 - *
 - *
 - *
 - *

Spoils Pile Surcharge Load



=====

STABLPro for Windows, Version 2015.4.5

Upgraded from:
FHWA-PCSTABLE

Serial Number : 357267753

--Slope Stability Analysis--
Simplified Janbu, Simplified Bishop
or Spencer Method of Slices

=====

This program is licensed to :

Korpi Cannon Engineering PLLC
Las Vegas, NV, USA

Path to file locations :

D:\Dropbox\Korpi_Cannon_Engineering\Projects\KC-0119 - MZB Engineering\Design\Excav
- Shoring\12.0 Haven\Design\4 ft\

Name of input data file : 7. Spoil - Vert.sl4d
Name of output file : 7. Spoil - Vert.sl4o
Name of plot output file : 7. Spoil - Vert.sl4p

Time and Date of Analysis

Date: February 02, 2026 Time: 15:29:09

1

PROBLEM DESCRIPTION New Slope

BOUNDARY COORDINATES

4 Top Boundaries
5 Total Boundaries

Boundary No.	X-Left ft.	Y-Left ft.	X-Right ft.	Y-Right ft.	Soil Type Below Bnd
1	0.00	9.00	30.00	9.00	2
2	30.00	9.00	30.25	13.00	2
3	30.25	13.00	38.25	21.00	1
4	38.25	21.00	75.00	21.00	1
5	30.25	13.00	75.00	13.00	2

1

ISOTROPIC SOIL PARAMETERS

2 Type(s) of Soil

Soil Type No.	Total Unit Wt. pcf	Saturated Unit Wt. pcf	Cohesion Intercept psf	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant psf	Piez. Surface No.
1	110.0	110.0	100.0	28.0	0.00	0.0	0
2	110.0	110.0	25.0	40.0	0.00	0.0	0

1

BOUNDARY LOAD(S)

7 Load(s) Specified

Load No.	X-Left ft.	X-Right ft.	Intensity psf	Deflection (deg)
1	41.25	43.25	230.0	0.0
2	43.25	45.25	690.0	0.0
3	45.25	47.25	1150.0	0.0
4	47.25	49.25	1610.0	0.0
5	49.25	51.25	1150.0	0.0
6	51.25	53.25	690.0	0.0
7	53.25	55.25	230.0	0.0

NOTE - Intensity Is Specified As A Uniformly Distributed Force Acting On A Horizontally Projected Surface.

1

A Critical Failure Surface Searching Method, Using A Random

Technique For Generating Circular Surfaces, Has Been Specified.

100 Trial Surfaces Have Been Generated.

10 Surfaces Initiate From Each Of 10 Points Equally Spaced
Along The Ground Surface Between X = 0.00 ft.
and X = 30.20 ft.

Each Surface Terminates Between X = 36.00 ft.
and X = 75.00 ft.

Unless Further Limitations Were Imposed, The Minimum Elevation
At Which A Surface Extends Is Y = 0.00 ft.

2.40 ft. Line Segments Define Each Trial Failure Surface.

Restrictions Have Been Imposed Upon The Angle Of Initiation.
The Angle Has Been Restricted Between The Angles Of -25.0
And 0.0 deg.

1

Following Are Displayed The Ten Most Critical Of The Trial
Failure Surfaces Examined. They Are Ordered - Most Critical
First.

* * Safety Factors Are Calculated By The Modified Bishop Method * *

Failure Surface Specified By 17 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.78	9.00
2	19.14	8.55
3	21.52	8.28
4	23.92	8.19
5	26.32	8.27
6	28.70	8.52
7	31.06	8.96

8	33.39	9.56
9	35.66	10.34
10	37.87	11.28
11	40.00	12.38
12	42.04	13.64
13	43.99	15.04
14	45.83	16.58
15	47.55	18.26
16	49.14	20.05
17	49.86	21.00

Circle Center At X = 24.0 ; Y = 40.7 and Radius, 32.5

*** 1.299 ***

Individual data on the 25 slices

Slice No.	Width Ft	Weight Lbs	Water Force		Tie Force		Earthquake Force		Surcharge Load Lbs
			Top Lbs	Bot Lbs	Norm Lbs	Tan Lbs	Hor Lbs	Ver Lbs	
1	2.4	0.58E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2	2.4	0.15E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3	2.4	0.20E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4	2.4	0.20E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
5	2.4	0.16E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
6	1.3	0.51E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
7	0.2	0.61E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8	0.8	0.41E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
9	2.3	0.15E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
10	2.3	0.18E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
11	2.2	0.21E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
12	0.4	0.40E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
13	1.7	0.17E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
14	1.0	0.92E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
15	0.2	0.22E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
16	0.8	0.66E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.18E+03
17	1.2	0.92E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.28E+03
18	0.7	0.51E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.51E+03
19	1.3	0.75E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.87E+03
20	0.6	0.30E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.67E+03
21	1.4	0.58E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.16E+04
22	0.3	0.95E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.48E+03
23	1.6	0.32E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.26E+04

24 0.1 0.11E+02 0.00E+00 0.00E+00 0.00E+00 0.00E+00 0.00E+00 0.00E+00 0.18E+03
 25 0.6 0.27E+02 0.00E+00 0.00E+00 0.00E+00 0.00E+00 0.00E+00 0.00E+00 0.70E+03

 Failure Surface Specified By 17 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.78	9.00
2	19.09	8.37
3	21.45	7.94
4	23.84	7.72
5	26.24	7.71
6	28.64	7.91
7	31.00	8.31
8	33.32	8.92
9	35.58	9.73
10	37.76	10.74
11	39.84	11.93
12	41.82	13.30
13	43.66	14.84
14	45.36	16.53
15	46.91	18.36
16	48.30	20.32
17	48.69	21.00

Circle Center At X = 25.2 ; Y = 35.2 and Radius, 27.5

*** 1.355 ***

1

Failure Surface Specified By 11 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	23.49	9.00
2	25.84	8.51
3	28.24	8.48
4	30.60	8.93
5	32.82	9.83
6	34.83	11.14
7	36.55	12.82
8	37.90	14.80

9	38.84	17.01
10	39.33	19.36
11	39.35	21.00

Circle Center At X = 27.2 ; Y = 20.7 and Radius, 12.2

*** 1.427 ***

Failure Surface Specified By 11 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	30.20	12.21
2	32.59	12.04
3	34.99	12.12
4	37.37	12.46
5	39.70	13.04
6	41.95	13.86
7	44.11	14.92
8	46.14	16.20
9	48.02	17.68
10	49.74	19.36
11	51.11	21.00

Circle Center At X = 33.0 ; Y = 34.8 and Radius, 22.8

*** 1.440 ***

1

Failure Surface Specified By 13 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	26.84	9.00
2	29.20	8.54
3	31.60	8.40
4	33.99	8.56
5	36.35	9.02
6	38.62	9.79
7	40.78	10.84

8	42.78	12.16
9	44.60	13.73
10	46.20	15.52
11	47.56	17.49
12	48.65	19.63
13	49.14	21.00

Circle Center At X = 31.6 ; Y = 27.0 and Radius, 18.6

*** 1.444 ***

Failure Surface Specified By 19 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	13.42	9.00
2	15.70	8.23
3	18.03	7.66
4	20.39	7.27
5	22.79	7.07
6	25.19	7.07
7	27.58	7.26
8	29.95	7.65
9	32.28	8.22
10	34.55	8.98
11	36.76	9.93
12	38.88	11.04
13	40.91	12.33
14	42.83	13.78
15	44.62	15.37
16	46.28	17.11
17	47.79	18.97
18	49.15	20.95
19	49.17	21.00

Circle Center At X = 24.0 ; Y = 36.7 and Radius, 29.7

*** 1.446 ***

1

Failure Surface Specified By 19 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	13.42	9.00
2	15.69	8.22
3	18.02	7.63
4	20.39	7.23
5	22.78	7.01
6	25.18	6.99
7	27.57	7.16
8	29.94	7.51
9	32.28	8.06
10	34.57	8.79
11	36.79	9.69
12	38.93	10.78
13	40.98	12.03
14	42.92	13.43
15	44.75	14.99
16	46.44	16.69
17	48.00	18.52
18	49.40	20.47
19	49.72	21.00

Circle Center At X = 24.3 ; Y = 37.1 and Radius, 30.1

*** 1.460 ***

Failure Surface Specified By 13 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	20.13	9.00
2	22.46	8.41
3	24.84	8.14
4	27.24	8.19
5	29.62	8.56
6	31.92	9.24
7	34.10	10.23
8	36.14	11.50
9	37.99	13.03
10	39.61	14.79
11	40.99	16.76
12	42.09	18.89
13	42.83	21.00

Circle Center At X = 25.7 ; Y = 26.0 and Radius, 17.9

*** 1.490 ***

1

Failure Surface Specified By 16 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	23.49	9.00
2	25.87	8.68
3	28.27	8.55
4	30.66	8.61
5	33.05	8.85
6	35.41	9.28
7	37.74	9.89
8	40.00	10.68
9	42.20	11.64
10	44.32	12.77
11	46.34	14.06
12	48.26	15.50
13	50.06	17.09
14	51.73	18.81
15	53.26	20.66
16	53.51	21.00

Circle Center At X = 28.7 ; Y = 39.4 and Radius, 30.9

*** 1.500 ***

Failure Surface Specified By 18 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.78	9.00
2	19.10	8.40
3	21.46	7.96
4	23.85	7.69
5	26.24	7.60

CAT 330 C EXCAVATOR SURCHARGE LOADING ANALYSIS


Total Equipment Weight $P := 77400 \cdot lb$ Per Richie Specs

Equipment Weight Per Track $P2 := \frac{P}{2} = 38700 \text{ lb}$ Number of Tracks = 2


Width of Equipment Track (N2) $N2 := \frac{34 \cdot in}{12 \cdot \frac{in}{ft}} = 2.833 \text{ ft}$ $N := 34 \cdot in$

Length of Track (D) $D := 13.25 \cdot ft$

Excavator Surcharge Weight (wt) $wt := \frac{P2}{D \cdot N2} = 1031 \frac{lb}{ft^2}$ Per Track



$$F := 8.42 \cdot ft$$



Corrected N-value for (ML) Sandy Silt

$$N_{field} := 10$$

Field measured Blow Counts

$$E_H := 0.6$$

Donut/Ring

$$C_B := 1$$

2.5 inch

$$C_S := 1$$

Standard Sampler

$$C_R := 0.75$$

Rod Length (10ft-13ft)

$$N_{60} := E_H \cdot C_B \cdot C_S \cdot C_R \cdot N_{field} = 4.5$$

Corrected N-value

Cohesion

$$c := 100 \text{ psf}$$

Typical for Compacted soil

Internal angle of Friction

$$\phi := 28 \text{ deg}$$

Caltrans Trench & Shoring
Manuel (Table 3.1)

Corrected N-value for (SM) Silty Sand

$$N_{field} := 100$$

Field measured Blow Counts

$$E_H := 0.6$$

Donut/Ring

$$C_B := 1$$

2.5 inch

$$C_S := 1$$

Standard Sampler

$$C_R := 0.75$$

Rod Length (10ft-13ft)

$$N_{60} := E_H \cdot C_B \cdot C_S \cdot C_R \cdot N_{field} = 45$$

Corrected N-value

Cohesion

$$c := 25 \text{ psf}$$

Typical for Compacted soil

Internal angle of Friction

$$\phi := 40 \text{ deg}$$

Caltrans Trench & Shoring
Manuel (Table 3.1)

Slope Stability Analysis (5 ft Vertical)




[TEL:702.808.1295](tel:702.808.1295)

KORPI CANNON ENGINEERING, PLLC

Scott@korpicanon.com

www.korpieng.com

1031 PSF Excavator Surcharge



=====

STABLPro for Windows, Version 2015.4.5

Upgraded from:
FHWA-PCSTABLE

Serial Number : 357267753

--Slope Stability Analysis--
Simplified Janbu, Simplified Bishop
or Spencer Method of Slices

=====

This program is licensed to :

Korpi Cannon Engineering PLLC
Las Vegas, NV, USA

Path to file locations :

D:\Dropbox\Korpi_Cannon_Engineering\Projects\KC-0119 - MZB Engineering\Design\Excav
- Shoring\12.0 Haven\Design\5 ft\

Name of input data file : 3. Excavator.sl4d
Name of output file : 3. Excavator.sl4o
Name of plot output file : 3. Excavator.sl4p

Time and Date of Analysis

Date: February 02, 2026 Time: 14:45:37

1

PROBLEM DESCRIPTION New Slope

BOUNDARY COORDINATES

4 Top Boundaries
5 Total Boundaries

Boundary No.	X-Left ft.	Y-Left ft.	X-Right ft.	Y-Right ft.	Soil Type Below Bnd
1	0.00	10.00	30.00	10.00	2
2	30.00	10.00	30.25	15.00	2
3	30.25	15.00	38.25	23.00	1
4	38.25	23.00	75.00	23.00	1
5	30.25	15.00	75.00	15.00	2

1

ISOTROPIC SOIL PARAMETERS

2 Type(s) of Soil

Soil Type No.	Total Unit Wt. pcf	Saturated Unit Wt. pcf	Cohesion Intercept psf	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant psf	Piez. Surface No.
1	110.0	110.0	100.0	28.0	0.00	0.0	0
2	110.0	110.0	25.0	41.0	0.00	0.0	0

1

BOUNDARY LOAD(S)

2 Load(s) Specified

Load No.	X-Left ft.	X-Right ft.	Intensity psf	Deflection (deg)
1	41.25	43.50	1031.0	0.0
2	49.75	52.00	1031.0	0.0

NOTE - Intensity Is Specified As A Uniformly Distributed Force Acting On A Horizontally Projected Surface.

1

A Critical Failure Surface Searching Method, Using A Random Technique For Generating Circular Surfaces, Has Been Specified.

100 Trial Surfaces Have Been Generated.

10 Surfaces Initiate From Each Of 10 Points Equally Spaced
Along The Ground Surface Between X = 0.00 ft.
and X = 30.17 ft.

Each Surface Terminates Between X = 34.00 ft.
and X = 75.00 ft.

Unless Further Limitations Were Imposed, The Minimum Elevation
At Which A Surface Extends Is Y = 0.00 ft.

2.60 ft. Line Segments Define Each Trial Failure Surface.

Restrictions Have Been Imposed Upon The Angle Of Initiation.
The Angle Has Been Restricted Between The Angles Of -25.0
And 0.0 deg.

1

Following Are Displayed The Ten Most Critical Of The Trial
Failure Surfaces Examined. They Are Ordered - Most Critical
First.

* * Safety Factors Are Calculated By The Modified Bishop Method * *

Failure Surface Specified By 12 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	23.47	10.00
2	26.01	9.48
3	28.61	9.38
4	31.19	9.69
5	33.69	10.40
6	36.05	11.50
7	38.20	12.97
8	40.09	14.75
9	41.67	16.82
10	42.91	19.10
11	43.76	21.56
12	44.02	23.00

Circle Center At X = 28.0 ; Y = 25.7 and Radius, 16.3

*** 1.356 ***

Individual data on the 17 slices

Slice No.	Width Ft	Weight Lbs	Water Force		Tie Force		Earthquake Force		Surcharge Load Lbs
			Top Lbs	Bot Lbs	Norm Lbs	Tan Lbs	Hor Lbs	Ver Lbs	
1	2.5	0.72E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2	2.6	0.16E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3	1.4	0.82E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4	0.2	0.81E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
5	0.9	0.61E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
6	2.5	0.20E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
7	2.4	0.22E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8	2.1	0.23E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
9	0.1	0.57E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
10	1.8	0.18E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
11	0.2	0.17E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
12	1.0	0.79E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
13	0.4	0.30E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.43E+03
14	1.2	0.68E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.13E+04
15	0.6	0.20E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.61E+03
16	0.3	0.53E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
17	0.3	0.20E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Failure Surface Specified By 13 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	20.11	10.00
2	22.59	9.19
3	25.15	8.76
4	27.75	8.71
5	30.33	9.04
6	32.83	9.75
7	35.20	10.82
8	37.38	12.23

9	39.34	13.95
10	41.02	15.93
11	42.38	18.14
12	43.41	20.53
13	44.06	23.00

Circle Center At X = 26.8 ; Y = 26.3 and Radius, 17.6

*** 1.424 ***

1

Failure Surface Specified By 15 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.76	10.00
2	19.26	9.28
3	21.82	8.83
4	24.42	8.67
5	27.01	8.79
6	29.58	9.19
7	32.09	9.87
8	34.52	10.81
9	36.82	12.01
10	38.98	13.46
11	40.97	15.13
12	42.77	17.01
13	44.35	19.07
14	45.70	21.29
15	46.50	23.00

Circle Center At X = 24.6 ; Y = 32.6 and Radius, 23.9

*** 1.536 ***

Failure Surface Specified By 13 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	20.11	10.00

2	22.53	9.04
3	25.08	8.51
4	27.67	8.43
5	30.25	8.80
6	32.72	9.61
7	35.01	10.84
8	37.06	12.44
9	38.79	14.38
10	40.17	16.58
11	41.15	18.99
12	41.69	21.54
13	41.74	23.00

Circle Center At X = 26.8 ; Y = 23.4 and Radius, 15.0

*** 1.643 ***

1

Failure Surface Specified By 16 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.76	10.00
2	19.23	9.20
3	21.78	8.67
4	24.37	8.42
5	26.97	8.46
6	29.55	8.78
7	32.08	9.38
8	34.53	10.25
9	36.87	11.39
10	39.07	12.77
11	41.10	14.39
12	42.95	16.22
13	44.59	18.24
14	45.99	20.43
15	47.15	22.75
16	47.25	23.00

Circle Center At X = 25.3 ; Y = 32.2 and Radius, 23.8

*** 1.651 ***

Failure Surface Specified By 13 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	23.47	10.00
2	26.02	9.50
3	28.61	9.33
4	31.21	9.50
5	33.76	10.01
6	36.22	10.83
7	38.56	11.97
8	40.73	13.40
9	42.70	15.10
10	44.44	17.03
11	45.90	19.18
12	47.09	21.50
13	47.62	23.00

Circle Center At X = 28.6 ; Y = 29.5 and Radius, 20.1

*** 1.668 ***

1

Failure Surface Specified By 16 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.76	10.00
2	19.13	8.93
3	21.62	8.18
4	24.19	7.75
5	26.78	7.66
6	29.37	7.90
7	31.91	8.47
8	34.35	9.37
9	36.66	10.56
10	38.79	12.05
11	40.72	13.80
12	42.40	15.78
13	43.82	17.96
14	44.94	20.30
15	45.76	22.77

16 45.80 23.00

Circle Center At X = 26.2 ; Y = 27.8 and Radius, 20.2

*** 1.720 ***

Failure Surface Specified By 17 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	13.41	10.00
2	15.87	9.17
3	18.41	8.58
4	20.98	8.23
5	23.58	8.13
6	26.18	8.28
7	28.75	8.67
8	31.27	9.30
9	33.72	10.17
10	36.07	11.27
11	38.32	12.59
12	40.42	14.11
13	42.37	15.83
14	44.15	17.73
15	45.74	19.78
16	47.13	21.98
17	47.65	23.00

Circle Center At X = 23.4 ; Y = 35.5 and Radius, 27.3

*** 1.726 ***

1

Failure Surface Specified By 17 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.76	10.00
2	19.30	9.43
3	21.87	9.07

4	24.47	8.93
5	27.07	9.01
6	29.65	9.30
7	32.20	9.81
8	34.70	10.52
9	37.13	11.45
10	39.48	12.57
11	41.72	13.88
12	43.85	15.38
13	45.85	17.04
14	47.70	18.87
15	49.39	20.84
16	50.91	22.95
17	50.94	23.00

Circle Center At X = 24.9 ; Y = 40.1 and Radius, 31.2

*** 1.754 ***

Failure Surface Specified By 17 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	13.41	10.00
2	15.87	9.16
3	18.40	8.55
4	20.97	8.19
5	23.57	8.06
6	26.17	8.18
7	28.74	8.54
8	31.27	9.14
9	33.73	9.97
10	36.11	11.03
11	38.37	12.31
12	40.51	13.79
13	42.50	15.46
14	44.32	17.32
15	45.96	19.33
16	47.41	21.49
17	48.23	23.00


Circle Center At X = 23.6 ; Y = 35.9 and Radius, 27.8

*** 1.792 ***

	Y	A	X	I	S	F	T
	0.00	9.38	18.75	28.13	37.50	46.88	
X	0.00	+-----+*	+-----+	+-----+	+-----+	+-----+	+-----+
	-
	9.38	+883
A	18.75	+ ...838.232	...78.129	...731.
X	28.13	+21.742* . *71.23...713.71..
I	37.50	+521..63265124 4. . /1965121 4 49 673 21 11/95685377
S	46.88	+ 6539.. .09.../2992/
	56.25	+

		-
		-
F	65.63	+
		-
		-
		-
		-
		-
T	75.00	+	*	.*

300 PSF Traffic Surcharge
200 PSF K-Rail Surcharge



=====

STABLPro for Windows, Version 2015.4.5

Upgraded from:
FHWA-PCSTABLE

Serial Number : 357267753

--Slope Stability Analysis--
Simplified Janbu, Simplified Bishop
or Spencer Method of Slices

=====

This program is licensed to :

Korpi Cannon Engineering PLLC
Las Vegas, NV, USA

Path to file locations :

D:\Dropbox\Korpi_Cannon_Engineering\Projects\KC-0119 - MZB Engineering\Design\Excav
- Shoring\12.0 Haven\Design\5 ft\

Name of input data file : 4. Traffic - Vert.sl4d
Name of output file : 4. Traffic - Vert.sl4o
Name of plot output file : 4. Traffic - Vert.sl4p

Time and Date of Analysis

Date: February 02, 2026 Time: 14:49:10

1

PROBLEM DESCRIPTION New Slope

BOUNDARY COORDINATES

4 Top Boundaries
5 Total Boundaries

Boundary No.	X-Left ft.	Y-Left ft.	X-Right ft.	Y-Right ft.	Soil Type Below Bnd
1	0.00	10.00	30.00	10.00	2
2	30.00	10.00	30.25	15.00	2
3	30.25	15.00	38.25	23.00	1
4	38.25	23.00	75.00	23.00	1
5	30.25	15.00	75.00	15.00	2

1

ISOTROPIC SOIL PARAMETERS

2 Type(s) of Soil

Soil Type No.	Total Unit Wt. pcf	Saturated Unit Wt. pcf	Cohesion Intercept psf	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant psf	Piez. Surface No.
1	110.0	110.0	100.0	28.0	0.00	0.0	0
2	110.0	110.0	25.0	40.0	0.00	0.0	0

1

BOUNDARY LOAD(S)

2 Load(s) Specified

Load No.	X-Left ft.	X-Right ft.	Intensity psf	Deflection (deg)
1	40.25	42.25	200.0	0.0
2	42.50	75.00	300.0	0.0

NOTE - Intensity Is Specified As A Uniformly Distributed Force Acting On A Horizontally Projected Surface.

1

A Critical Failure Surface Searching Method, Using A Random Technique For Generating Circular Surfaces, Has Been Specified.

100 Trial Surfaces Have Been Generated.

10 Surfaces Initiate From Each Of 10 Points Equally Spaced
Along The Ground Surface Between X = 0.00 ft.
and X = 30.20 ft.

Each Surface Terminates Between X = 35.00 ft.
and X = 75.00 ft.

Unless Further Limitations Were Imposed, The Minimum Elevation
At Which A Surface Extends Is Y = 0.00 ft.

2.60 ft. Line Segments Define Each Trial Failure Surface.

Restrictions Have Been Imposed Upon The Angle Of Initiation.
The Angle Has Been Restricted Between The Angles Of -25.0
And 0.0 deg.

1

Following Are Displayed The Ten Most Critical Of The Trial
Failure Surfaces Examined. They Are Ordered - Most Critical
First.

* * Safety Factors Are Calculated By The Modified Bishop Method * *

Failure Surface Specified By 12 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	20.13	10.00
2	22.63	9.27
3	25.22	8.99
4	27.81	9.17
5	30.33	9.79
6	32.71	10.84
7	34.87	12.28
8	36.75	14.08
9	38.29	16.18
10	39.43	18.51
11	40.16	21.01
12	40.38	23.00

Circle Center At X = 25.5 ; Y = 23.9 and Radius, 14.9

*** 1.469 ***

Individual data on the 16 slices

Slice No.	Width Ft	Weight Lbs	Water Force		Tie Force		Earthquake Force		Surcharge Load Lbs
			Top Lbs	Bot Lbs	Norm Lbs	Tan Lbs	Hor Lbs	Ver Lbs	
1	2.5	0.10E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2	2.6	0.25E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3	2.6	0.26E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4	2.2	0.14E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
5	0.2	0.76E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
6	0.1	0.49E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
7	2.4	0.16E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8	2.2	0.17E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
9	1.9	0.15E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
10	0.7	0.54E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
11	0.8	0.64E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
12	0.0	0.27E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
13	1.1	0.71E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
14	0.7	0.26E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
15	0.1	0.16E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
16	0.1	0.79E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.25E+02

Failure Surface Specified By 12 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	23.49	10.00
2	26.04	9.48
3	28.63	9.35
4	31.22	9.59
5	33.75	10.21
6	36.16	11.19
7	38.39	12.51
8	40.42	14.15
9	42.18	16.06

10	43.64	18.21
11	44.77	20.55
12	45.54	23.00

Circle Center At X = 28.3 ; Y = 27.1 and Radius, 17.7

*** 1.521 ***

1

Failure Surface Specified By 13 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	20.13	10.00
2	22.59	9.16
3	25.16	8.73
4	27.76	8.72
5	30.32	9.14
6	32.79	9.96
7	35.08	11.18
8	37.15	12.76
9	38.93	14.65
10	40.38	16.81
11	41.46	19.18
12	42.14	21.69
13	42.28	23.00

Circle Center At X = 26.5 ; Y = 24.6 and Radius, 15.9

*** 1.542 ***

Failure Surface Specified By 16 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.78	10.00
2	19.28	9.28
3	21.84	8.82
4	24.43	8.64
5	27.03	8.72

6	29.60	9.08
7	32.13	9.70
8	34.57	10.58
9	36.91	11.72
10	39.12	13.09
11	41.18	14.68
12	43.05	16.48
13	44.73	18.47
14	46.19	20.62
15	47.42	22.91
16	47.46	23.00

Circle Center At X = 24.9 ; Y = 33.5 and Radius, 24.9

*** 1.592 ***

1

Failure Surface Specified By 16 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.78	10.00
2	19.25	9.20
3	21.79	8.66
4	24.38	8.39
5	26.98	8.39
6	29.57	8.67
7	32.11	9.22
8	34.58	10.03
9	36.95	11.09
10	39.20	12.40
11	41.29	13.94
12	43.22	15.69
13	44.95	17.63
14	46.46	19.74
15	47.75	22.00
16	48.19	23.00

Circle Center At X = 25.6 ; Y = 33.1 and Radius, 24.7

*** 1.670 ***

Failure Surface Specified By 14 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	23.49	10.00
2	26.04	9.50
3	28.63	9.31
4	31.23	9.43
5	33.80	9.86
6	36.29	10.59
7	38.68	11.62
8	40.93	12.92
9	43.01	14.49
10	44.88	16.29
11	46.53	18.30
12	47.92	20.49
13	49.05	22.84
14	49.10	23.00

Circle Center At X = 28.9 ; Y = 31.0 and Radius, 21.7

*** 1.671 ***

1

Failure Surface Specified By 17 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	13.42	10.00
2	15.89	9.17
3	18.42	8.57
4	20.99	8.21
5	23.59	8.09
6	26.19	8.21
7	28.76	8.56
8	31.29	9.16
9	33.76	9.98
10	36.14	11.03
11	38.41	12.30
12	40.56	13.77
13	42.56	15.43
14	44.39	17.26
15	46.06	19.26

16	47.53	21.41
17	48.41	23.00

Circle Center At X = 23.6 ; Y = 36.2 and Radius, 28.1

*** 1.724 ***

Failure Surface Specified By 17 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.78	10.00
2	19.32	9.43
3	21.89	9.07
4	24.49	8.91
5	27.08	8.97
6	29.67	9.23
7	32.23	9.70
8	34.74	10.38
9	37.19	11.25
10	39.56	12.32
11	41.83	13.58
12	44.00	15.02
13	46.04	16.62
14	47.95	18.39
15	49.71	20.30
16	51.31	22.35
17	51.74	23.00

Circle Center At X = 25.1 ; Y = 41.2 and Radius, 32.3

*** 1.739 ***

1

Failure Surface Specified By 15 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	13.42	10.00
2	15.84	9.05

3	18.36	8.41
4	20.94	8.08
5	23.54	8.08
6	26.12	8.40
7	28.64	9.04
8	31.07	9.98
9	33.35	11.22
10	35.47	12.73
11	37.38	14.49
12	39.06	16.48
13	40.48	18.66
14	41.62	21.00
15	42.30	23.00

Circle Center At X = 22.3 ; Y = 29.0 and Radius, 20.9

*** 1.746 ***

Failure Surface Specified By 17 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	13.42	10.00
2	15.88	9.16
3	18.41	8.55
4	20.98	8.17
5	23.58	8.02
6	26.18	8.11
7	28.76	8.44
8	31.29	9.00
9	33.77	9.79
10	36.17	10.80
11	38.46	12.02
12	40.64	13.45
13	42.67	15.07
14	44.55	16.87
15	46.26	18.83
16	47.78	20.93
17	49.00	23.00


Circle Center At X = 23.9 ; Y = 36.6 and Radius, 28.6

*** 1.753 ***

	Y	A	X	I	S	F	T
	0.00	9.38	18.75	28.13	37.50	46.88	
X	0.00	+*-----+	+-----+	+-----+	+-----+	+-----+	
	-	
	9.38	+77	
	-447.141	
A	18.75	+ ...747.23142.31.	
	-51* .*29.431023162.9.	
X	28.13	+4.31.624 319 1624 3.9 1 1/18.72 3 93 31/2	
	-68542685472 26547448.65658...	
I	37.50	+88	
	-	
S	46.88	+	
	-	
	56.25	+	
	-	
	-	
	-	

		-	
F	65.63	+	
		-	
		-	
		-	
		-	
		-	
T	75.00	+	*		.*2/

3 CY Loader Surcharge



=====

STABLPro for Windows, Version 2015.4.5

Upgraded from:
FHWA-PCSTABLE

Serial Number : 357267753

--Slope Stability Analysis--
Simplified Janbu, Simplified Bishop
or Spencer Method of Slices

=====

This program is licensed to :

Korpi Cannon Engineering PLLC
Las Vegas, NV, USA

Path to file locations :

D:\Dropbox\Korpi_Cannon_Engineering\Projects\KC-0119 - MZB Engineering\Design\Excav
- Shoring\12.0 Haven\Design\5 ft\

Name of input data file : 5. Loader - Vert.sl4d
Name of output file : 5. Loader - Vert.sl4o
Name of plot output file : 5. Loader - Vert.sl4p

Time and Date of Analysis

Date: February 02, 2026 Time: 15:24:01

1

PROBLEM DESCRIPTION New Slope

BOUNDARY COORDINATES

4 Top Boundaries
5 Total Boundaries

Boundary No.	X-Left ft.	Y-Left ft.	X-Right ft.	Y-Right ft.	Soil Type Below Bnd
1	0.00	10.00	30.00	10.00	2
2	30.00	10.00	30.25	15.00	2
3	30.25	15.00	37.25	22.00	1
4	37.25	22.00	75.00	22.00	1
5	30.25	15.00	75.00	15.00	2

1

ISOTROPIC SOIL PARAMETERS

2 Type(s) of Soil

Soil Type No.	Total Unit Wt. pcf	Saturated Unit Wt. pcf	Cohesion Intercept psf	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant psf	Piez. Surface No.
1	110.0	110.0	100.0	28.0	0.00	0.0	0
2	110.0	110.0	25.0	40.0	0.00	0.0	0

1

BOUNDARY LOAD(S)

2 Load(s) Specified

Load No.	X-Left ft.	X-Right ft.	Intensity psf	Deflection (deg)
1	46.25	48.00	4700.0	0.0
2	54.25	56.00	4700.0	0.0

NOTE - Intensity Is Specified As A Uniformly Distributed Force Acting On A Horizontally Projected Surface.

1

A Critical Failure Surface Searching Method, Using A Random Technique For Generating Circular Surfaces, Has Been Specified.

100 Trial Surfaces Have Been Generated.

10 Surfaces Initiate From Each Of 10 Points Equally Spaced
Along The Ground Surface Between X = 0.00 ft.
and X = 30.20 ft.

Each Surface Terminates Between X = 35.00 ft.
and X = 75.00 ft.

Unless Further Limitations Were Imposed, The Minimum Elevation
At Which A Surface Extends Is Y = 0.00 ft.

2.60 ft. Line Segments Define Each Trial Failure Surface.

Restrictions Have Been Imposed Upon The Angle Of Initiation.
The Angle Has Been Restricted Between The Angles Of -25.0
And 0.0 deg.

1

Following Are Displayed The Ten Most Critical Of The Trial
Failure Surfaces Examined. They Are Ordered - Most Critical
First.

* * Safety Factors Are Calculated By The Modified Bishop Method * *

Failure Surface Specified By 13 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	23.49	10.00
2	26.04	9.50
3	28.63	9.31
4	31.23	9.42
5	33.80	9.84
6	36.29	10.57
7	38.69	11.58
8	40.95	12.87
9	43.03	14.42
10	44.93	16.20
11	46.59	18.20
12	48.01	20.38

13 48.81 22.00

Circle Center At X = 29.0 ; Y = 31.2 and Radius, 21.9

*** 1.273 ***

Individual data on the 18 slices

Slice No.	Width Ft	Weight Lbs	Water Force		Tie Force		Earthquake Force		Surcharge Load Lbs
			Top Lbs	Bot Lbs	Norm Lbs	Tan Lbs	Hor Lbs	Ver Lbs	
1	2.6	0.70E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2	2.6	0.17E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3	1.4	0.10E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4	0.2	0.86E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
5	1.0	0.66E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
6	2.6	0.22E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
7	2.5	0.26E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8	1.0	0.11E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
9	1.4	0.17E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
10	2.3	0.24E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
11	2.1	0.19E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
12	0.6	0.50E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
13	1.3	0.90E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
14	1.3	0.73E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
15	0.3	0.15E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.16E+04
16	1.4	0.42E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.66E+04
17	0.0	0.16E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
18	0.8	0.71E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Failure Surface Specified By 16 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.78	10.00
2	19.25	9.20
3	21.79	8.66
4	24.38	8.38
5	26.98	8.38
6	29.57	8.65

7	32.11	9.19
8	34.58	9.99
9	36.96	11.04
10	39.21	12.34
11	41.32	13.86
12	43.26	15.60
13	45.00	17.53
14	46.53	19.63
15	47.84	21.88
16	47.90	22.00

Circle Center At X = 25.7 ; Y = 33.2 and Radius, 24.9

*** 1.293 ***

1

Failure Surface Specified By 17 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	13.42	10.00
2	15.88	9.16
3	18.41	8.55
4	20.98	8.16
5	23.58	8.01
6	26.18	8.10
7	28.76	8.42
8	31.30	8.97
9	33.78	9.75
10	36.18	10.74
11	38.48	11.96
12	40.66	13.37
13	42.71	14.97
14	44.60	16.76
15	46.32	18.71
16	47.86	20.80
17	48.59	22.00

Circle Center At X = 23.9 ; Y = 36.8 and Radius, 28.8

*** 1.372 ***

Failure Surface Specified By 15 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.78	10.00
2	19.28	9.28
3	21.84	8.82
4	24.43	8.63
5	27.03	8.71
6	29.60	9.06
7	32.13	9.68
8	34.58	10.55
9	36.93	11.67
10	39.14	13.03
11	41.21	14.61
12	43.09	16.40
13	44.79	18.37
14	46.27	20.51
15	47.08	22.00

Circle Center At X = 25.0 ; Y = 33.7 and Radius, 25.0

*** 1.438 ***

1

Failure Surface Specified By 18 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	10.07	10.00
2	12.53	9.17
3	15.05	8.54
4	17.62	8.11
5	20.21	7.88
6	22.81	7.85
7	25.40	8.03
8	27.97	8.42
9	30.51	9.00
10	32.99	9.78
11	35.40	10.76
12	37.72	11.92
13	39.95	13.26
14	42.06	14.78

15	44.05	16.45
16	45.90	18.28
17	47.61	20.24
18	48.90	22.00

Circle Center At X = 21.8 ; Y = 40.9 and Radius, 33.0

*** 1.448 ***

Failure Surface Specified By 14 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	23.49	10.00
2	26.02	9.42
3	28.61	9.13
4	31.21	9.13
5	33.79	9.42
6	36.33	9.99
7	38.79	10.84
8	41.13	11.95
9	43.34	13.32
10	45.39	14.93
11	47.24	16.75
12	48.88	18.77
13	50.28	20.96
14	50.80	22.00

Circle Center At X = 29.9 ; Y = 32.5 and Radius, 23.4

*** 1.479 ***

1

Failure Surface Specified By 16 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.78	10.00
2	19.32	9.43
3	21.89	9.07

4	24.48	8.91
5	27.08	8.95
6	29.67	9.21
7	32.23	9.67
8	34.74	10.33
9	37.20	11.19
10	39.57	12.25
11	41.86	13.49
12	44.04	14.90
13	46.10	16.49
14	48.03	18.24
15	49.81	20.13
16	51.30	22.00

Circle Center At X = 25.2 ; Y = 41.5 and Radius, 32.6

*** 1.479 ***

Failure Surface Specified By 12 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	20.13	10.00
2	22.63	9.27
3	25.22	8.99
4	27.81	9.16
5	30.34	9.78
6	32.72	10.82
7	34.88	12.27
8	36.76	14.06
9	38.30	16.15
10	39.46	18.48
11	40.19	20.98
12	40.31	22.00

Circle Center At X = 25.5 ; Y = 23.9 and Radius, 15.0

*** 1.516 ***

1

Failure Surface Specified By 18 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	10.07	10.00
2	12.48	9.02
3	14.96	8.26
4	17.51	7.72
5	20.09	7.41
6	22.69	7.33
7	25.28	7.48
8	27.85	7.85
9	30.38	8.46
10	32.85	9.28
11	35.23	10.32
12	37.52	11.56
13	39.68	13.01
14	41.71	14.63
15	43.58	16.44
16	45.29	18.39
17	46.82	20.50
18	47.72	22.00

Circle Center At X = 22.3 ; Y = 36.7 and Radius, 29.4

*** 1.517 ***

Failure Surface Specified By 18 Coordinate Points


Point No.	X-Surf ft.	Y-Surf ft.
1	13.42	10.00
2	15.83	9.03
3	18.32	8.27
4	20.87	7.74
5	23.45	7.44
6	26.05	7.37
7	28.64	7.53
8	31.21	7.93
9	33.74	8.55
10	36.20	9.39
11	38.57	10.45
12	40.84	11.72
13	42.99	13.18
14	45.00	14.83

15	46.85	16.66
16	48.54	18.64
17	50.04	20.76
18	50.75	22.00

Circle Center At X = 25.5 ; Y = 36.5 and Radius, 29.1

*** 1.610 ***

1




```

- .....76 111/
- .....760
- .....6
- .....
- ...../2
56.25 + .....2/
- .....
- .....
- .....
- .....
- .....
F 65.63 + .....
- .....
- .....
- .....
- .....
- .....
T 75.00 + * *

```

Concrete Truck Surcharge Load



=====

STABLPro for Windows, Version 2015.4.5

Upgraded from:
FHWA-PCSTABLE

Serial Number : 357267753

--Slope Stability Analysis--
Simplified Janbu, Simplified Bishop
or Spencer Method of Slices

=====

This program is licensed to :

Korpi Cannon Engineering PLLC
Las Vegas, NV, USA

Path to file locations :

D:\Dropbox\Korpi_Cannon_Engineering\Projects\KC-0119 - MZB Engineering\Design\Excav
- Shoring\12.0 Haven\Design\5 ft\

Name of input data file : 6. Concrete Truck - Vert.sl4d
Name of output file : 6. Concrete Truck - Vert.sl4o
Name of plot output file : 6. Concrete Truck - Vert.sl4p

Time and Date of Analysis

Date: February 02, 2026 Time: 14:33:58

1

PROBLEM DESCRIPTION New Slope

BOUNDARY COORDINATES

4 Top Boundaries
5 Total Boundaries

Boundary No.	X-Left ft.	Y-Left ft.	X-Right ft.	Y-Right ft.	Soil Type Below Bnd
1	0.00	10.00	30.00	10.00	2
2	30.00	10.00	30.25	15.00	2
3	30.25	15.00	38.25	23.00	1
4	38.25	23.00	75.00	23.00	1
5	30.25	15.00	75.00	15.00	2

1

ISOTROPIC SOIL PARAMETERS

2 Type(s) of Soil

Soil Type No.	Total Unit Wt. pcf	Saturated Unit Wt. pcf	Cohesion Intercept psf	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant psf	Piez. Surface No.
1	110.0	110.0	100.0	28.0	0.00	0.0	0
2	110.0	110.0	25.0	40.0	0.00	0.0	0

1

BOUNDARY LOAD(S)

1 Load(s) Specified

Load No.	X-Left ft.	X-Right ft.	Intensity psf	Deflection (deg)
1	50.25	54.25	3361.0	0.0

NOTE - Intensity Is Specified As A Uniformly Distributed Force Acting On A Horizontally Projected Surface.

1

A Critical Failure Surface Searching Method, Using A Random Technique For Generating Circular Surfaces, Has Been Specified.

100 Trial Surfaces Have Been Generated.

10 Surfaces Initiate From Each Of 10 Points Equally Spaced
Along The Ground Surface Between X = 0.00 ft.
and X = 30.20 ft.

Each Surface Terminates Between X = 35.00 ft.
and X = 75.00 ft.

Unless Further Limitations Were Imposed, The Minimum Elevation
At Which A Surface Extends Is Y = 0.00 ft.

2.60 ft. Line Segments Define Each Trial Failure Surface.

Restrictions Have Been Imposed Upon The Angle Of Initiation.
The Angle Has Been Restricted Between The Angles Of -25.0
And 0.0 deg.

1

Following Are Displayed The Ten Most Critical Of The Trial
Failure Surfaces Examined. They Are Ordered - Most Critical
First.

* * Safety Factors Are Calculated By The Modified Bishop Method * *

Failure Surface Specified By 14 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	26.84	10.00
2	29.44	9.94
3	32.04	10.10
4	34.61	10.47
5	37.15	11.04
6	39.63	11.82
7	42.04	12.80
8	44.36	13.97
9	46.58	15.33
10	48.68	16.86
11	50.65	18.56
12	52.47	20.41
13	54.14	22.41

14 54.55 23.00

Circle Center At X = 28.8 ; Y = 41.8 and Radius, 31.9

*** 1.303 ***

Individual data on the 19 slices

Slice No.	Width Ft	Weight Lbs	Water Force		Tie Force		Earthquake Force		Surcharge Load Lbs
			Top Lbs	Bot Lbs	Norm Lbs	Tan Lbs	Hor Lbs	Ver Lbs	
1	2.6	0.80E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2	0.6	0.24E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3	0.2	0.69E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4	1.8	0.12E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
5	2.6	0.22E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
6	2.5	0.28E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
7	1.1	0.14E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8	1.4	0.17E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
9	2.4	0.28E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
10	2.3	0.25E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
11	1.7	0.16E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
12	0.5	0.46E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
13	2.1	0.16E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
14	1.6	0.94E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
15	0.4	0.20E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.13E+04
16	1.8	0.70E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.61E+04
17	1.7	0.29E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.56E+04
18	0.1	0.64E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.38E+03
19	0.3	0.72E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Failure Surface Specified By 13 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	26.84	10.00
2	29.44	9.83
3	32.04	9.90
4	34.62	10.23
5	37.16	10.79

6	39.63	11.60
7	42.01	12.64
8	44.29	13.90
9	46.43	15.37
10	48.42	17.04
11	50.25	18.89
12	51.89	20.90
13	53.29	23.00

Circle Center At X = 29.9 ; Y = 37.1 and Radius, 27.3

*** 1.351 ***

1

Failure Surface Specified By 18 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.78	10.00
2	19.27	9.26
3	21.82	8.72
4	24.39	8.40
5	26.99	8.28
6	29.59	8.37
7	32.17	8.67
8	34.72	9.18
9	37.22	9.90
10	39.66	10.81
11	42.01	11.92
12	44.26	13.21
13	46.41	14.69
14	48.42	16.33
15	50.30	18.13
16	52.02	20.07
17	53.59	22.15
18	54.13	23.00

Circle Center At X = 27.2 ; Y = 40.4 and Radius, 32.1

*** 1.371 ***

Failure Surface Specified By 11 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	30.20	14.01
2	32.79	13.83
3	35.39	13.90
4	37.97	14.23
5	40.51	14.81
6	42.97	15.64
7	45.35	16.70
8	47.60	17.99
9	49.72	19.49
10	51.69	21.20
11	53.39	23.00

Circle Center At X = 33.3 ; Y = 40.4 and Radius, 26.5

*** 1.425 ***

1

Failure Surface Specified By 12 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	30.20	14.01
2	32.76	13.56
3	35.36	13.40
4	37.95	13.55
5	40.51	13.99
6	43.01	14.72
7	45.40	15.74
8	47.66	17.02
9	49.76	18.56
10	51.67	20.33
11	53.36	22.30
12	53.83	23.00

Circle Center At X = 35.4 ; Y = 36.0 and Radius, 22.6

*** 1.463 ***

Failure Surface Specified By 12 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	20.13	10.00
2	22.63	9.27
3	25.22	8.99
4	27.81	9.17
5	30.33	9.79
6	32.71	10.84
7	34.87	12.28
8	36.75	14.08
9	38.29	16.18
10	39.43	18.51
11	40.16	21.01
12	40.38	23.00

Circle Center At X = 25.5 ; Y = 23.9 and Radius, 14.9

*** 1.472 ***

1

Failure Surface Specified By 17 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.78	10.00
2	19.32	9.43
3	21.89	9.07
4	24.49	8.91
5	27.08	8.97
6	29.67	9.23
7	32.23	9.70
8	34.74	10.38
9	37.19	11.25
10	39.56	12.32
11	41.83	13.58
12	44.00	15.02
13	46.04	16.62
14	47.95	18.39
15	49.71	20.30
16	51.31	22.35

17 51.74 23.00

Circle Center At X = 25.1 ; Y = 41.2 and Radius, 32.3

*** 1.513 ***

Failure Surface Specified By 13 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	20.13	10.00
2	22.59	9.16
3	25.16	8.73
4	27.76	8.72
5	30.32	9.14
6	32.79	9.96
7	35.08	11.18
8	37.15	12.76
9	38.93	14.65
10	40.38	16.81
11	41.46	19.18
12	42.14	21.69
13	42.28	23.00

Circle Center At X = 26.5 ; Y = 24.6 and Radius, 15.9

*** 1.600 ***

1

Failure Surface Specified By 20 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	13.42	10.00
2	15.85	9.07
3	18.34	8.31
4	20.88	7.75
5	23.45	7.37
6	26.04	7.18
7	28.64	7.18

8	31.23	7.38
9	33.81	7.76
10	36.34	8.33
11	38.83	9.09
12	41.25	10.02
13	43.60	11.14
14	45.87	12.42
15	48.03	13.86
16	50.08	15.46
17	52.00	17.21
18	53.80	19.09
19	55.45	21.10
20	56.78	23.00

Circle Center At X = 27.3 ; Y = 42.5 and Radius, 35.3

*** 1.650 ***

Failure Surface Specified By 24 Coordinate Points


Point No.	X-Surf ft.	Y-Surf ft.
1	0.00	10.00
2	2.49	9.25
3	5.01	8.62
4	7.56	8.11
5	10.13	7.72
6	12.72	7.46
7	15.32	7.33
8	17.92	7.32
9	20.51	7.44
10	23.10	7.68
11	25.68	8.05
12	28.23	8.54
13	30.75	9.16
14	33.25	9.89
15	35.70	10.75
16	38.11	11.73
17	40.47	12.82
18	42.78	14.02
19	45.02	15.33
20	47.20	16.75
21	49.31	18.28
22	51.34	19.90
23	53.29	21.62

24 54.71 23.00

Circle Center At X = 16.8 ; Y = 61.0 and Radius, 53.7

*** 1.651 ***


1



```

- ..... 9 1032
- ..... ..9111/
56.25 + .....9
- ..... .
- .....
- .....
- .....
- .....
- .....
F 65.63 + .....
- .....
- .....
- .....
- .....
- .....
T 75.00 + * .....*
```

Spoils Pile Surcharge Load



=====

STABLPro for Windows, Version 2015.4.5

Upgraded from:
FHWA-PCSTABLE

Serial Number : 357267753

--Slope Stability Analysis--
Simplified Janbu, Simplified Bishop
or Spencer Method of Slices

=====

This program is licensed to :

Korpi Cannon Engineering PLLC
Las Vegas, NV, USA

Path to file locations :

D:\Dropbox\Korpi_Cannon_Engineering\Projects\KC-0119 - MZB Engineering\Design\Excav
- Shoring\12.0 Haven\Design\5 ft\

Name of input data file : 7. Spoil - Vert.sl4d
Name of output file : 7. Spoil - Vert.sl4o
Name of plot output file : 7. Spoil - Vert.sl4p

Time and Date of Analysis

Date: February 02, 2026 Time: 14:40:23

1

PROBLEM DESCRIPTION New Slope

BOUNDARY COORDINATES

4 Top Boundaries
5 Total Boundaries

Boundary No.	X-Left ft.	Y-Left ft.	X-Right ft.	Y-Right ft.	Soil Type Below Bnd
1	0.00	8.00	30.00	8.00	2
2	30.00	8.00	30.25	13.00	2
3	30.25	13.00	37.25	20.00	1
4	37.25	20.00	75.00	20.00	1
5	30.25	13.00	75.00	13.00	2

1

ISOTROPIC SOIL PARAMETERS

2 Type(s) of Soil

Soil Type No.	Total Unit Wt. pcf	Saturated Unit Wt. pcf	Cohesion Intercept psf	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant psf	Piez. Surface No.
1	110.0	110.0	100.0	28.0	0.00	0.0	0
2	110.0	110.0	25.0	40.0	0.00	0.0	0

1

BOUNDARY LOAD(S)

7 Load(s) Specified

Load No.	X-Left ft.	X-Right ft.	Intensity psf	Deflection (deg)
1	40.25	42.25	230.0	0.0
2	42.25	44.25	690.0	0.0
3	44.25	46.25	1150.0	0.0
4	47.25	48.25	1610.0	0.0
5	48.25	50.25	1150.0	0.0
6	50.25	52.25	690.0	0.0
7	52.25	54.25	230.0	0.0

NOTE - Intensity Is Specified As A Uniformly Distributed Force Acting On A Horizontally Projected Surface.

1

A Critical Failure Surface Searching Method, Using A Random

Technique For Generating Circular Surfaces, Has Been Specified.

100 Trial Surfaces Have Been Generated.

10 Surfaces Initiate From Each Of 10 Points Equally Spaced
Along The Ground Surface Between X = 0.00 ft.
and X = 30.20 ft.

Each Surface Terminates Between X = 36.00 ft.
and X = 75.00 ft.

Unless Further Limitations Were Imposed, The Minimum Elevation
At Which A Surface Extends Is Y = 0.00 ft.

2.40 ft. Line Segments Define Each Trial Failure Surface.

Restrictions Have Been Imposed Upon The Angle Of Initiation.
The Angle Has Been Restricted Between The Angles Of -25.0
And 0.0 deg.

1

Following Are Displayed The Ten Most Critical Of The Trial
Failure Surfaces Examined. They Are Ordered - Most Critical
First.

* * Safety Factors Are Calculated By The Modified Bishop Method * *

Failure Surface Specified By 17 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.78	8.00
2	19.14	7.55
3	21.52	7.28
4	23.92	7.19
5	26.32	7.29
6	28.70	7.56
7	31.06	8.00

8	33.38	8.63
9	35.64	9.42
10	37.84	10.39
11	39.96	11.51
12	41.99	12.79
13	43.92	14.23
14	45.73	15.80
15	47.42	17.50
16	48.98	19.32
17	49.48	20.00

Circle Center At X = 23.9 ; Y = 39.2 and Radius, 32.0

*** 1.386 ***

Individual data on the 26 slices

Slice No.	Width Ft	Weight Lbs	Water Force		Tie Force		Earthquake Force		Surcharge Load Lbs
			Top Lbs	Bot Lbs	Norm Lbs	Tan Lbs	Hor Lbs	Ver Lbs	
1	2.4	0.58E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2	2.4	0.15E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3	2.4	0.20E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4	2.4	0.20E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
5	2.4	0.15E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
6	1.3	0.46E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
7	0.2	0.74E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8	0.8	0.49E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
9	2.3	0.17E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
10	2.3	0.21E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
11	1.6	0.17E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
12	0.6	0.63E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
13	2.1	0.21E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
14	0.3	0.27E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
15	1.7	0.15E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.40E+03
16	0.3	0.20E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.60E+02
17	0.0	0.12E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.10E+02
18	1.7	0.12E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.11E+04
19	0.3	0.21E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.23E+03
20	1.5	0.79E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.17E+04
21	0.5	0.23E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.60E+03
22	1.0	0.35E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
23	0.2	0.49E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.28E+03

24	0.8	0.18E+03	0.00E+00	0.13E+04						
25	0.7	0.89E+02	0.00E+00	0.84E+03						
26	0.5	0.18E+02	0.00E+00	0.57E+03						

Failure Surface Specified By 13 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	23.49	8.00
2	25.84	7.52
3	28.23	7.34
4	30.63	7.46
5	33.00	7.87
6	35.29	8.57
7	37.48	9.54
8	39.54	10.78
9	41.42	12.27
10	43.11	13.97
11	44.58	15.88
12	45.79	17.94
13	46.68	20.00

Circle Center At X = 28.5 ; Y = 26.7 and Radius, 19.4

*** 1.414 ***

1

Failure Surface Specified By 16 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.78	8.00
2	19.10	7.39
3	21.47	7.00
4	23.86	6.84
5	26.26	6.90
6	28.65	7.18
7	30.99	7.69
8	33.28	8.41
9	35.49	9.34
10	37.60	10.48
11	39.60	11.81

12	41.47	13.32
13	43.18	15.00
14	44.73	16.83
15	46.11	18.80
16	46.79	20.00

Circle Center At X = 24.4 ; Y = 32.5 and Radius, 25.6

*** 1.416 ***

Failure Surface Specified By 17 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.78	8.00
2	19.09	7.37
3	21.46	6.94
4	23.85	6.73
5	26.25	6.72
6	28.64	6.93
7	31.00	7.35
8	33.32	7.98
9	35.57	8.80
10	37.74	9.83
11	39.81	11.04
12	41.77	12.43
13	43.60	13.98
14	45.28	15.70
15	46.80	17.55
16	48.16	19.53
17	48.42	20.00

Circle Center At X = 25.1 ; Y = 33.9 and Radius, 27.2

*** 1.438 ***

1

Failure Surface Specified By 15 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
-----------	------------	------------

1	20.13	8.00
2	22.42	7.26
3	24.77	6.79
4	27.16	6.61
5	29.56	6.72
6	31.93	7.11
7	34.23	7.79
8	36.44	8.74
9	38.51	9.94
10	40.43	11.38
11	42.16	13.05
12	43.67	14.91
13	44.96	16.94
14	45.99	19.10
15	46.29	20.00

Circle Center At X = 27.5 ; Y = 26.6 and Radius, 20.0

*** 1.450 ***

Failure Surface Specified By 16 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	16.78	8.00
2	19.05	7.23
3	21.39	6.70
4	23.78	6.43
5	26.18	6.41
6	28.56	6.66
7	30.91	7.15
8	33.19	7.90
9	35.38	8.89
10	37.45	10.11
11	39.37	11.54
12	41.13	13.17
13	42.71	14.98
14	44.08	16.95
15	45.23	19.06
16	45.62	20.00

Circle Center At X = 25.1 ; Y = 28.7 and Radius, 22.3

*** 1.470 ***

1

Failure Surface Specified By 18 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	13.42	8.00
2	15.70	7.23
3	18.03	6.66
4	20.40	6.28
5	22.79	6.09
6	25.19	6.10
7	27.58	6.30
8	29.95	6.70
9	32.27	7.29
10	34.54	8.08
11	36.74	9.04
12	38.85	10.18
13	40.86	11.49
14	42.76	12.96
15	44.53	14.58
16	46.16	16.34
17	47.64	18.23
18	48.80	20.00

Circle Center At X = 23.9 ; Y = 35.3 and Radius, 29.3

*** 1.537 ***

Failure Surface Specified By 19 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	13.42	8.00
2	15.69	7.22
3	18.02	6.64
4	20.39	6.24
5	22.78	6.03
6	25.18	6.01
7	27.57	6.19

8	29.94	6.56
9	32.28	7.13
10	34.56	7.87
11	36.77	8.80
12	38.90	9.91
13	40.93	11.18
14	42.86	12.61
15	44.66	14.20
16	46.33	15.92
17	47.86	17.77
18	49.23	19.74
19	49.38	20.00

Circle Center At X = 24.2 ; Y = 35.7 and Radius, 29.7

*** 1.552 ***

1

Failure Surface Specified By 9 Coordinate Points

Point No.	X-Surf ft.	Y-Surf ft.
1	30.20	12.01
2	32.60	11.96
3	34.97	12.34
4	37.23	13.15
5	39.31	14.35
6	41.13	15.91
7	42.64	17.78
8	43.79	19.89
9	43.83	20.00

Circle Center At X = 31.7 ; Y = 25.1 and Radius, 13.2

*** 1.568 ***

Failure Surface Specified By 14 Coordinate Points


Point No.	X-Surf ft.	Y-Surf ft.
-----------	------------	------------

1	20.13	8.00
2	22.36	7.11
3	24.70	6.55
4	27.08	6.31
5	29.48	6.42
6	31.84	6.85
7	34.12	7.62
8	36.26	8.69
9	38.24	10.06
10	40.00	11.68
11	41.52	13.54
12	42.76	15.60
13	43.71	17.80
14	44.30	20.00

Circle Center At X = 27.6 ; Y = 23.4 and Radius, 17.1

*** 1.602 ***

1



```

      - .....21. .9
      - .....57...9
      - .....21.....
I   37.50 + .....821..9 . . *
      - .....523.9. .
      - .....1 6..9. /1
      - .....21.60.9..1/2
      - .....13 60.92/3
      - .....8 13256
S   46.88 + .....7 1323/4
      - .....8 14/5
      - .....15/6
      - .....6/7
      - .....
      - .....7/
56.25 + .....
      - .....
      - .....
      - .....
      - .....
      - .....
F   65.63 + .....
      - .....
      - .....
      - .....
      - .....
      - .....
T   75.00 + .....
      * .....*
```

Reference Material



[TEL:702.808.1295](tel:702.808.1295)

KORPI CANNON ENGINEERING, PLLC

Scott@korpicanon.com

www.korpieng.com

9608 AQUA HARBOR WAY

LAS VEGAS, NV

89178

January 31, 2023

Project No. 22235-01

Mr. Matthew Blain
Brightsky Residential
9160 Irvine Center Drive, Suite 100
Irvine, CA 92618

Subject: Preliminary Geotechnical Evaluation for the Proposed Residential Development, Northwest Corner of Evans Road and Garbani Road, City of Menifee, California

In accordance with your request, LGC Geotechnical, Inc. has performed a geotechnical evaluation for the proposed residential development located at the northwest corner of Evans Road and Garbani Road in the City of Menifee, California. This report summarizes the results of our background review, subsurface exploration, and geotechnical analyses of the data collected, and presents our findings, conclusions, and preliminary recommendations for the proposed residential project.

If you should have any questions regarding this report, please do not hesitate to contact our office. We appreciate this opportunity to be of service.

Respectfully,

LGC Geotechnical, Inc.




Dennis Boratyne, GE 2770
Vice President




Branden Petersen, EIT
Senior Staff Engineer

DJB/BPP/MJG/amm

Distribution: (1) Addressee (electronic copy, wet signed copies can be provided upon request)





- Legend**
- TP-8 Approximate Location of Exploratory Test Pit by LGC Geotechnical, With Total Depth in Feet
 - HS-4 Approximate Location of Hollow Stem Auger Boring by LGC Geotechnical, With Total Depth in Feet
 - T.D. = 25' Approximate Location of Hollow Stem Auger Infiltration Boring by LGC Geotechnical, With Total Depth in Feet
 - I-2 Approximate Location of Hollow Stem Auger Infiltration Boring by LGC Geotechnical, With Total Depth in Feet
 - T.D. = 4' Approximate Location of Hollow Stem Auger Infiltration Boring by LGC Geotechnical, With Total Depth in Feet
 - 3 Approximate Removal Depth Below Existing Grade, Shown in Feet



LGC Geotechnical, Inc.
 131 Calle Iglesia, Ste. 200
 San Clemente, CA 92672
 TEL (949) 369-6141 FAX (949) 369-6142

FIGURE 2
Geotechnical Map

Page 132 of 138

PROJECT NAME	Brightsky - Garbani
PROJECT NO.	22235-01
ENG. / GEOL.	DJB
SCALE	1" = 100'
DATE	January 2023

Geotechnical Boring Log Borehole LGC-HS-1

Date: 1/12/2023	Drilling Company: 2R Drilling, Inc.
Project Name: Brightsky - Garbani	Type of Rig: CME 75
Project Number: 22235-01	Drop: 30" Hole Diameter: 8"
Elevation of Top of Hole: ~1508' MSL	Drive Weight: 140 pounds
Hole Location: See Geotechnical Map	Page 1 of 2

Elevation (ft)	Depth (ft)	Graphic Log	Sample Number	Blow Count	Dry Density (pcf)	Moisture (%)	USCS Symbol	DESCRIPTION	Type of Test
1505	0	B-1	R-1	10 11 11	106.4	7.0	CL/SC	<p>@0' to 5' - Quaternary Older Alluvium (Qof): @0'- Sandy SILT: light yellowish brown, moist; rootlets</p> <p>@2.5'- Sandy CLAY/Clayey SAND: reddish brown, slightly moist, verystiff/medium dense</p> <p>@5' to T.D. - Granodiorite to Tonalite (Kdvg): @5'- Silty SAND with Gravel: brown, dry, very dense</p> <p style="text-align: right; color: red;">Soil 1</p>	MD -#200 EI CR
1500	5		R-2	50/5"	114.1	4.3		<p>@7.5'- SAND: light yellowish brown, dry, very dense</p> <p style="text-align: right; color: red;">Soil 2</p>	
1495	10		R-3	50/1"	109.7	1.8	SP	@10'- SAND with Silt: light yellowish brown, dry, very dense	
1490	15		SPT-1	50/3"		8.9	SM	@15'- Silty SAND: pale brown, moist, very dense	
1485	20	▽	R-5	34 50/6"	122.9	6.3	SP-SM to CL	<p>@19'- Groundwater encountered.</p> <p>@20'- SAND with Silt to Sandy CLAY: light grayish brown, slightly moist/dry, very dense/hard</p>	
1480	25		SPT-2	50/6"		15.5	SC	@25'- Clayey SAND: grayish brown, wet, very dense	
	30								

	THIS SUMMARY APPLIES ONLY AT THE LOCATION OF THIS BORING AND AT THE TIME OF DRILLING. SUBSURFACE CONDITIONS MAY DIFFER AT OTHER LOCATIONS AND MAY CHANGE AT THIS LOCATION WITH THE PASSAGE OF TIME. THE DATA PRESENTED IS A SIMPLIFICATION OF THE ACTUAL CONDITIONS ENCOUNTERED. THE DESCRIPTIONS PROVIDED ARE QUALITATIVE FIELD DESCRIPTIONS AND ARE NOT BASED ON QUANTITATIVE ENGINEERING ANALYSIS.	<table border="0" style="width: 100%;"> <tr> <td>SAMPLE TYPES:</td> <td>TEST TYPES:</td> </tr> <tr> <td>B BULK SAMPLE</td> <td>DS DIRECT SHEAR</td> </tr> <tr> <td>R RING SAMPLE (CA Modified Sampler)</td> <td>MD MAXIMUM DENSITY</td> </tr> <tr> <td>G GRAB SAMPLE</td> <td>SA SIEVE ANALYSIS</td> </tr> <tr> <td>SPT STANDARD PENETRATION TEST SAMPLE</td> <td>S&H SIEVE AND HYDROMETER</td> </tr> <tr> <td></td> <td>EI EXPANSION INDEX</td> </tr> <tr> <td></td> <td>CN CONSOLIDATION</td> </tr> <tr> <td></td> <td>CR CORROSION</td> </tr> <tr> <td></td> <td>AL ATTERBERG LIMITS</td> </tr> <tr> <td></td> <td>CO COLLAPSE/SWELL</td> </tr> <tr> <td></td> <td>RV R-VALUE</td> </tr> <tr> <td></td> <td>#200 % PASSING # 200 SIEVE</td> </tr> </table>	SAMPLE TYPES:	TEST TYPES:	B BULK SAMPLE	DS DIRECT SHEAR	R RING SAMPLE (CA Modified Sampler)	MD MAXIMUM DENSITY	G GRAB SAMPLE	SA SIEVE ANALYSIS	SPT STANDARD PENETRATION TEST SAMPLE	S&H SIEVE AND HYDROMETER		EI EXPANSION INDEX		CN CONSOLIDATION		CR CORROSION		AL ATTERBERG LIMITS		CO COLLAPSE/SWELL		RV R-VALUE		#200 % PASSING # 200 SIEVE
SAMPLE TYPES:	TEST TYPES:																									
B BULK SAMPLE	DS DIRECT SHEAR																									
R RING SAMPLE (CA Modified Sampler)	MD MAXIMUM DENSITY																									
G GRAB SAMPLE	SA SIEVE ANALYSIS																									
SPT STANDARD PENETRATION TEST SAMPLE	S&H SIEVE AND HYDROMETER																									
	EI EXPANSION INDEX																									
	CN CONSOLIDATION																									
	CR CORROSION																									
	AL ATTERBERG LIMITS																									
	CO COLLAPSE/SWELL																									
	RV R-VALUE																									
	#200 % PASSING # 200 SIEVE																									

Geotechnical Boring Log Borehole LGC-HS-1

Date: 1/12/2023	Drilling Company: 2R Drilling, Inc.
Project Name: Brightsky - Garbani	Type of Rig: CME 75
Project Number: 22235-01	Drop: 30" Hole Diameter: 8"
Elevation of Top of Hole: ~1508' MSL	Drive Weight: 140 pounds
Hole Location: See Geotechnical Map	Page 2 of 2

Elevation (ft)	Depth (ft)	Graphic Log	Sample Number	Blow Count	Dry Density (pcf)	Moisture (%)	USCS Symbol	DESCRIPTION	Type of Test
1475	30		R-6	50/2.5"	116.2	22.0	SM	@30'- Silty SAND with Gravel: olive brown, wet, very dense	
1470	35		SPT-3	50/0.5"		11.4		@35'- Silty SAND: grayish brown, moist, very dense	
1465	40							Total Depth = 36' Groundwater Encountered at Approximately 19' Backfilled with Cuttings on 1/12/2023	
1460	45								
1455	50								
1450	55								
	60								



THIS SUMMARY APPLIES ONLY AT THE LOCATION OF THIS BORING AND AT THE TIME OF DRILLING. SUBSURFACE CONDITIONS MAY DIFFER AT OTHER LOCATIONS AND MAY CHANGE AT THIS LOCATION WITH THE PASSAGE OF TIME. THE DATA PRESENTED IS A SIMPLIFICATION OF THE ACTUAL CONDITIONS ENCOUNTERED. THE DESCRIPTIONS PROVIDED ARE QUALITATIVE FIELD DESCRIPTIONS AND ARE NOT BASED ON QUANTITATIVE ENGINEERING ANALYSIS.

<p>SAMPLE TYPES:</p> <p>B BULK SAMPLE R RING SAMPLE (CA Modified Sampler) G GRAB SAMPLE SPT STANDARD PENETRATION TEST SAMPLE</p> <p> GROUNDWATER TABLE</p>	<p>TEST TYPES:</p> <p>DS DIRECT SHEAR MD MAXIMUM DENSITY SA SIEVE ANALYSIS S&H SIEVE AND HYDROMETER EI EXPANSION INDEX CN CONSOLIDATION CR CORROSION AL ATTERBERG LIMITS CO COLLAPSE/SWELL RV R-VALUE #200 % PASSING # 200 SIEVE</p>
--	---

Geotechnical Boring Log Borehole LGC-HS-2

Date: 1/12/2023	Drilling Company: 2R Drilling, Inc.
Project Name: Brightsky - Garbani	Type of Rig: CME 75
Project Number: 22235-01	Drop: 30" Hole Diameter: 8"
Elevation of Top of Hole: ~1516' MSL	Drive Weight: 140 pounds
Hole Location: See Geotechnical Map	Page 1 of 1

Elevation (ft)	Depth (ft)	Graphic Log	Sample Number	Blow Count	Dry Density (pcf)	Moisture (%)	USCS Symbol	DESCRIPTION	Type of Test
1515	0		R-1	7 7 7	96.0	8.7	ML	@0' to 7.5' - Quaternary Older Alluvium (Qof): @0'- Sandy SILT: yellowish brown to reddish brown, moist @2.5'- Sandy SILT: reddish brown, slightly moist, stiff	
1510	5		R-2	7 9 15	112.8	7.5	SC	@5'- Clayey SAND: brown, slightly moist, medium dense	CO
			R-3	50/4"	115.9	5.2	SP-SM	@7.5' to T.D. - Granodiorite to Tonalite (Kdvg):	Soil 1
1505	10		R-4	50/6"	111.8	5.3	SM	@7.5'- SAND to SAND with Silt: reddish brown, slightly moist, very dense @10'- Silty SAND: light reddish brown, slightly moist, very dense	Soil 2
1500	15		SPT-1	50/3"		4.1		@15'- Silty SAND: light brown. dry, very dense	
1495	20	▽	R-5	50/1"	110.8	7.4	SM/ML	@20'- Silty SAND/Sandy SILT: light brown, slightly moist, very dense/hard @21.5'- Groundwater Encountered	
1490	25		SPT-2	35 50/5"		8.4	SM	@25'- Silty SAND: brown, moist, very dense	
	30							Total Depth = 25' Groundwater Encountered at Approximately 21.5' Backfilled with Cuttings on 1/12/2023	

	THIS SUMMARY APPLIES ONLY AT THE LOCATION OF THIS BORING AND AT THE TIME OF DRILLING. SUBSURFACE CONDITIONS MAY DIFFER AT OTHER LOCATIONS AND MAY CHANGE AT THIS LOCATION WITH THE PASSAGE OF TIME. THE DATA PRESENTED IS A SIMPLIFICATION OF THE ACTUAL CONDITIONS ENCOUNTERED. THE DESCRIPTIONS PROVIDED ARE QUALITATIVE FIELD DESCRIPTIONS AND ARE NOT BASED ON QUANTITATIVE ENGINEERING ANALYSIS.	<table border="0"> <tr> <td>SAMPLE TYPES:</td> <td>TEST TYPES:</td> </tr> <tr> <td>B BULK SAMPLE</td> <td>DS DIRECT SHEAR</td> </tr> <tr> <td>R RING SAMPLE (CA Modified Sampler)</td> <td>MD MAXIMUM DENSITY</td> </tr> <tr> <td>G GRAB SAMPLE</td> <td>SA SIEVE ANALYSIS</td> </tr> <tr> <td>SPT STANDARD PENETRATION TEST SAMPLE</td> <td>S&H SIEVE AND HYDROMETER</td> </tr> <tr> <td></td> <td>EI EXPANSION INDEX</td> </tr> <tr> <td></td> <td>CN CONSOLIDATION</td> </tr> <tr> <td></td> <td>CR CORROSION</td> </tr> <tr> <td></td> <td>AL ATTERBERG LIMITS</td> </tr> <tr> <td style="text-align: center;">▽ GROUNDWATER TABLE</td> <td>CO COLLAPSE/SWELL</td> </tr> <tr> <td></td> <td>RV R-VALUE</td> </tr> <tr> <td></td> <td>#200 % PASSING # 200 SIEVE</td> </tr> </table>	SAMPLE TYPES:	TEST TYPES:	B BULK SAMPLE	DS DIRECT SHEAR	R RING SAMPLE (CA Modified Sampler)	MD MAXIMUM DENSITY	G GRAB SAMPLE	SA SIEVE ANALYSIS	SPT STANDARD PENETRATION TEST SAMPLE	S&H SIEVE AND HYDROMETER		EI EXPANSION INDEX		CN CONSOLIDATION		CR CORROSION		AL ATTERBERG LIMITS	▽ GROUNDWATER TABLE	CO COLLAPSE/SWELL		RV R-VALUE		#200 % PASSING # 200 SIEVE
SAMPLE TYPES:	TEST TYPES:																									
B BULK SAMPLE	DS DIRECT SHEAR																									
R RING SAMPLE (CA Modified Sampler)	MD MAXIMUM DENSITY																									
G GRAB SAMPLE	SA SIEVE ANALYSIS																									
SPT STANDARD PENETRATION TEST SAMPLE	S&H SIEVE AND HYDROMETER																									
	EI EXPANSION INDEX																									
	CN CONSOLIDATION																									
	CR CORROSION																									
	AL ATTERBERG LIMITS																									
▽ GROUNDWATER TABLE	CO COLLAPSE/SWELL																									
	RV R-VALUE																									
	#200 % PASSING # 200 SIEVE																									

Geotechnical Boring Log Borehole LGC-HS-3

Date: 1/12/2023	Drilling Company: 2R Drilling, Inc.
Project Name: Brightsky - Garbani	Type of Rig: CME 75
Project Number: 22235-01	Drop: 30" Hole Diameter: 8"
Elevation of Top of Hole: ~1508' MSL	Drive Weight: 140 pounds
Hole Location: See Geotechnical Map	Page 1 of 1

Elevation (ft)	Depth (ft)	Graphic Log	Sample Number	Blow Count	Dry Density (pcf)	Moisture (%)	USCS Symbol	DESCRIPTION	Type of Test
1505	0		R-1	21 21 19	111.0	10.5	SM	@0' to 2.5' - Quaternary Older Alluvium (Qof): @0'- Sandy SILT with Gravel: yellowish brown to reddish brown, moist @2.5' to T.D. - Granodiorite to Tonalite (Kdvg): @2.5'- Silty SAND: brown, moist, dense	
	5		R-2	38 50/3"	111.7	8.7	SP-SM		@5'- SAND to SAND with Silt: reddish brown, moist, very dense
1500			R-3	50/2"	107.1	6.3	SM	@7.5'- Silty SAND: yellowish brown, slightly moist, very dense	Soil 2
	10		R-4	50/1"	109.3	2.9	SP-SM	@10'- SAND to Silty SAND: light olive brown, dry, very dense	
1495			SPT-1	50/5"		5.0	SM	@15'- Silty SAND: pale yellowish brown, slightly moist, very dense	
1490			R-5	50/1"	114.3	2.1		@20'- Silty SAND with Gravel: light brown, dry, very dense	
1485			SPT-2	50/1"		2.9	SP-SM	@25'- SAND with Silt: pale grayish brown, dry, very dense	
1480								Total Depth = 25' Groundwater Not Encountered Backfilled with Cuttings on 1/12/2023	
	30								

	THIS SUMMARY APPLIES ONLY AT THE LOCATION OF THIS BORING AND AT THE TIME OF DRILLING. SUBSURFACE CONDITIONS MAY DIFFER AT OTHER LOCATIONS AND MAY CHANGE AT THIS LOCATION WITH THE PASSAGE OF TIME. THE DATA PRESENTED IS A SIMPLIFICATION OF THE ACTUAL CONDITIONS ENCOUNTERED. THE DESCRIPTIONS PROVIDED ARE QUALITATIVE FIELD DESCRIPTIONS AND ARE NOT BASED ON QUANTITATIVE ENGINEERING ANALYSIS.	<table style="width: 100%;"> <tr> <td>SAMPLE TYPES:</td> <td>TEST TYPES:</td> </tr> <tr> <td>B BULK SAMPLE</td> <td>DS DIRECT SHEAR</td> </tr> <tr> <td>R RING SAMPLE (CA Modified Sampler)</td> <td>MD MAXIMUM DENSITY</td> </tr> <tr> <td>G GRAB SAMPLE</td> <td>SA SIEVE ANALYSIS</td> </tr> <tr> <td>SPT STANDARD PENETRATION TEST SAMPLE</td> <td>S&H SIEVE AND HYDROMETER</td> </tr> <tr> <td></td> <td>EI EXPANSION INDEX</td> </tr> <tr> <td></td> <td>CN CONSOLIDATION</td> </tr> <tr> <td></td> <td>CR CORROSION</td> </tr> <tr> <td></td> <td>AL ATTERBERG LIMITS</td> </tr> <tr> <td></td> <td>CO COLLAPSE/SWELL</td> </tr> <tr> <td></td> <td>RV R-VALUE</td> </tr> <tr> <td></td> <td>#200 % PASSING # 200 SIEVE</td> </tr> </table>	SAMPLE TYPES:	TEST TYPES:	B BULK SAMPLE	DS DIRECT SHEAR	R RING SAMPLE (CA Modified Sampler)	MD MAXIMUM DENSITY	G GRAB SAMPLE	SA SIEVE ANALYSIS	SPT STANDARD PENETRATION TEST SAMPLE	S&H SIEVE AND HYDROMETER		EI EXPANSION INDEX		CN CONSOLIDATION		CR CORROSION		AL ATTERBERG LIMITS		CO COLLAPSE/SWELL		RV R-VALUE		#200 % PASSING # 200 SIEVE
SAMPLE TYPES:	TEST TYPES:																									
B BULK SAMPLE	DS DIRECT SHEAR																									
R RING SAMPLE (CA Modified Sampler)	MD MAXIMUM DENSITY																									
G GRAB SAMPLE	SA SIEVE ANALYSIS																									
SPT STANDARD PENETRATION TEST SAMPLE	S&H SIEVE AND HYDROMETER																									
	EI EXPANSION INDEX																									
	CN CONSOLIDATION																									
	CR CORROSION																									
	AL ATTERBERG LIMITS																									
	CO COLLAPSE/SWELL																									
	RV R-VALUE																									
	#200 % PASSING # 200 SIEVE																									

Geotechnical Boring Log Borehole LGC-HS-4

Date: 1/12/2023	Drilling Company: 2R Drilling, Inc.
Project Name: Brightsky - Garbani	Type of Rig: CME 75
Project Number: 22235-01	Drop: 30" Hole Diameter: 8"
Elevation of Top of Hole: ~1502' MSL	Drive Weight: 140 pounds
Hole Location: See Geotechnical Map	Page 1 of 1

Elevation (ft)	Depth (ft)	Graphic Log	Sample Number	Blow Count	Dry Density (pcf)	Moisture (%)	USCS Symbol	DESCRIPTION	Type of Test
1500	0		R-1	10 14 50/4"	120.6	9.3	ML-SM	@0' to 2.5' - Quaternary Older Alluvium (Qof): @0'- Sandy SILT with Gravel: yellowish brown to reddish brown, moist; organics; rootlets @2.5' to T.D. - Granodiorite to Tonalite (Kdvg): @2.5'- SILT to Silty SAND with Gravel: brown, slightly moist/moist, hard/very dense @5'- Silty SAND with Gravel: light brown, dry, very dense @7.5'- SAND with Silt: light brown, dry, very dense	
	5		R-2	50/2"	100.5	2.6	SM		
1495			R-3	50/2"	106.5	3.1	SM		Soil 1
1490	10		R-4	50/2"	112.1	2.2	SM	@10'- Silty SAND: light brown, dry, very dense	Soil 2
1485	15		SPT-1	50/0.5"		3.2		@15'- Silty SAND with Gravel: yellowish brown, dry, very dense	
1480	20		R-5	50/1"	106.8	5.0		@20'- Silty SAND with Gravel: brown, slightly moist, very dense	
1475	25		SPT-2	50/2"		2.5		@25'- Silty SAND: pale brown, dry, very dense	
								Total Depth = 25' Groundwater Not Encountered Backfilled with Cuttings on 1/12/2023	



THIS SUMMARY APPLIES ONLY AT THE LOCATION OF THIS BORING AND AT THE TIME OF DRILLING. SUBSURFACE CONDITIONS MAY DIFFER AT OTHER LOCATIONS AND MAY CHANGE AT THIS LOCATION WITH THE PASSAGE OF TIME. THE DATA PRESENTED IS A SIMPLIFICATION OF THE ACTUAL CONDITIONS ENCOUNTERED. THE DESCRIPTIONS PROVIDED ARE QUALITATIVE FIELD DESCRIPTIONS AND ARE NOT BASED ON QUANTITATIVE ENGINEERING ANALYSIS.

SAMPLE TYPES: B BULK SAMPLE R RING SAMPLE (CA Modified Sampler) G GRAB SAMPLE SPT STANDARD PENETRATION TEST SAMPLE GROUNDWATER TABLE	TEST TYPES: DS DIRECT SHEAR MD MAXIMUM DENSITY SA SIEVE ANALYSIS S&H SIEVE AND HYDROMETER EI EXPANSION INDEX CN CONSOLIDATION CR CORROSION AL ATTERBERG LIMITS CO COLLAPSE/SWELL RV R-VALUE #200 % PASSING # 200 SIEVE
--	--

3.3 STANDARD PENETRATION TEST (SPT)

The Standard Penetration Test (SPT) obtains a disturbed sample of soil for visual identification and description, and/or laboratory testing (particle size analysis, plasticity index). The number of hammer blows required to drive the 12^k sampler, is referred to as N value. When corrected for the SPT hammer's energy efficiency, it becomes N_{60} . This can be used to determine the apparent density of a granular soil. Empirical relationships to approximate the soil friction angle (ϕ) and density are shown in Table 3-1.

Table 3-1. Properties Granular Soils

Apparent Density	Relative Density (%)	SPT, N_{60} (blows/ft)	Friction Angle, ϕ (deg)	Unit Weight (pcf)	
				Moist	Submerged
Very Loose	0-15	$N_{60} < 5$	<28	<100	<60
Loose	16-35	$5 \leq N_{60} < 10$	28-30	95-125	55-65
Medium Dense	36-65	$10 \leq N_{60} < 30$	31-36	110-130	60-70
Dense	66-85	$30 \leq N_{60} < 50$	37-41	110-140	65-85
Very Dense	86-100	$N_{60} \geq 50$	>41	>130	>75

Note that both the LOTB and BR report the SPT blow count observed in the field as the N value, not N_{60} as used above to determine the apparent density descriptor. The reader is encouraged to read the Logging Manual on Apparent Density and Appendix A.8 on SPT prior to using Table 3-1. Note: there are a variety of correction factors that can be applied to the N value such as for overburden pressure. It is important to know what, if any, correction factors have been applied to the N value for the correct interpretation of Table 3-1.

The Division of Engineering Services, Office of Geotechnical Services has prepared a summary of "simplified typical soil values." For average trench conditions, the Engineer will find the data very useful to establish basic properties or evaluate data submitted by the contractor. Table 3-2 lists approximate values.